



Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pathways-13	Hallway Outside Women's Locker Room, Right Bubbler	B	8:34 AM	5	ND <sup>3</sup>	N	First Draw
Pathways-14	Room 113, Faucet	F	8:33 AM	5	1	Y	First Draw
Pathways-15	Multipurpose Room, Water Cooler	WC	8:40 AM	5	ND	N	First Draw. Water cooler was reviewed against the EPA Fact Sheet to determine that it is not a lead lined.

Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pathways - 01	Room 113, 2-Compartment Faucet	F	8:07 AM	5	1	Y	First Draw
Pathways - 02	Room 112, Kitchen Faucet	KF	8:14 AM	5	5	Y	First Draw
Pathways - 03	Hallway, Outside Women's Locker Room, Left Bubbler	B	8:05 AM	5	ND	N	First Draw
Pathways - 04	Hallway, Outside Room 402, Bubbler	B	8:40 AM	5	7	N	First Draw. Low Flow.
Pathways - 05	Hallway, Outside Room 208 Bottle Fill	BT	8:30 AM	5	3	N	First Draw
Pathways - 06	Hallway, Outside Room 200, Bubbler	B	8:17 AM	5	ND	N	First Draw
Pathways - 07	Hallway, Between Men's and Women's Bathrooms, 300 Hall, Bubbler	B	8:19 AM	5	ND	N	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminante>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested

Action Level >5ppb



Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pathways - 08	Hallway, Outside Room 310, Bottle Fill	BT	8:22 AM	5	ND	N	First Draw
Pathways - 09	Staff Lounge, 2-Compartment Faucet	KF	8:36 AM	5	ND	Y	First Draw
Pathways - 16	Hallway, Outside Room 208, Bottle Fill, Water Cooler	BT	8:28 AM	5	5	N	First Draw
Pathways - 10	Media Center, Teacher Workroom, Faucet	WC	N/A	5	N/A	N	Sink is Leaking, Did not Sample.
Pathways - 17	Hallway, Outside Room 310, Bottle Fill, Water Cooler	BT	8:24 AM	5	ND	N	First Draw

Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pathways - 11	3-Compartment Sink, Kitchen Faucet	KF	1:35 PM	5	1	N	First Draw
Pathways - 12	3-Compartment Sink, Kitchen Sprayer	KS	1:35 PM	5	6	N	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminante>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested

Action Level >5ppb