



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE220030**

Ann Arbor Open at Mack School							
Date of Sampling: February 5, 2022							
Sampler: Zachary Fortin							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
A2SOM-06	Kitchen, 3-Compartment Sink, Far Left Add On Faucet, Kitchen Faucet	KF	3:49 PM	5	ND <sup>3</sup>	Y	First Draw, Filtered.
A2SOM-09	Room 261, Combination Sink, Glass Filler	C	4:28 PM	5	ND	N	First Draw, Filtered.
A2SOM-16	Hallway, Floor 3, In-between Room 303/305, Hydration Station, Bottle Fill	HS	4:43 PM	5	ND	Y	First Draw, Filtered.
A2SOM-18	Hallway, Floor 1, Outside Room 109B, Hydration Station, Bottle Fill	HS	4:50 PM	5	ND	Y	First Draw, Filtered.
A2SOM-32	Room 233, Combination Sink, Glass Filler	C	4:01 PM	5	ND	N	First Draw, Filtered.
A2SOM-40	Room 241, Combination Sink, Glass Filler	C	4:06 PM	5	ND	N	First Draw, Filtered.
A2SOM-44	Room 245, Combination Sink, Glass Filler	C	4:10 PM	5	ND	N	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools**  
**Lead Drinking Water Analysis**  
**Project Number: AE220030**

Ann Arbor Open at Mack School							
Date of Sampling: February 5, 2022							
Sampler: Zachary Fortin							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
A2SOM-50	Room 251, Combination Sink, Glass Filler	C	4:16 PM	5	ND	N	First Draw, Filtered.
A2SOM-56	Room 257, Combination Sink, Glass Filler	C	4:21 PM	5	ND	N	First Draw, Filtered.
A2SOM-61	Gym Entrance Door, Outside Men's Locker Room, Hydration Station, Bottle Fill	HS	3:39 PM	5	ND	N	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb