



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Abbot Elementary School							
Date of Sampling: January 22, 2022							
Sampler: Victoria Vo							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Abbot-05	Kitchen, 3-Compartment, Far Left Add on Faucet, Kitchen Faucet	KF	5:28 PM	5	ND ³	Y	First Draw, Filtered.
Abbot-08	Room D-2, Stainless Glass Filler	G	5:49 PM	5	ND	N	First Draw, Filtered.
Abbot-10	Room D-4, Stainless Glass Filler	G	5:47 PM	5	ND	N	First Draw, Filtered.
Abbot-16	Room D-7, Island Near Door, Combination Sink, Glass Filler	C	5:44 PM	5	ND	N	First Draw, Filtered.
Abbot-19	Room C-10, Combination Sink, Glass Filler	C	5:40 PM	5	ND	N	First Draw, Filtered.
Abbot-25	Room C-7, Stainless Glass Filler	G	5:36 PM	5	ND	N	First Draw, Filtered.

- 1) Type: B = Bubblers, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Abbot Elementary School							
Date of Sampling: January 22, 2022							
Sampler: Victoria Vo							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Abbot-32	Room A-5, Stainless Glass Filler	G	5:22 PM	5	ND	N	First Draw, Filtered.
Abbot-35	Room A-8, Stainless Glass Filler	G	5:19 PM	5	ND	N	First Draw, Filtered.
Abbot-38	A Hall Centrum, Hydration Station, Bottle Fill	HS	5:15 PM	5	ND	Y	First Draw, Filtered.
Abbot-40	Hallway, Outside Room B-2, Hydration Station, Bottle Fill	HS	5:33 PM	5	ND	Y	First Draw, Filtered.

- 1) Type: B = Bubler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb