



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Allen Elementary School							
Date of Sampling: January 29, 2022							
Sampler: Sabrina Fouche							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Allen-02	Room K-3, Combination Sink, Glass Filler	C	1:53 PM	5	ND ³	Y	First Draw, Filtered.
Allen-07	Room A-17, Combination Sink, Glass Filler	C	2:08 PM	5	ND	Y	First Draw, Filtered.
Allen-11	Room B-22, Combination Sink, Glass Filler	C	2:13 PM	5	ND	Y	First Draw, Filtered.
Allen-17	Room A-19, Combination Sink, Glass Filler	C	2:04 PM	5	ND	Y	First Draw, Filtered.
Allen-24	Room A-21, Combination Sink, Glass Filler	C	2:01 PM	5	ND	Y	First Draw, Filtered.
Allen-32	Room C-9, Combination Sink, Glass Filler	C	1:50 PM	5	ND	Y	First Draw, Filtered.
Allen-40	Room K-1, Combination Sink, Glass Filler	C	1:56 PM	5	ND	Y	First Draw, Filtered.
Allen-49	Room B-25, Combination Sink, Glass Filler	C	2:16 PM	5	ND	Y	First Draw, Filtered.

- 1) Type: B = Bubblers, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Allen Elementary School							
Date of Sampling: January 29, 2022							
Sampler: Sabrina Fouche							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Allen-52	Hallway, Outside of Computer Lab, Hydration Station, Bottle Fill	HS	1:43 PM	5	ND	Y	First Draw, Filtered.
Allen-58	Room CL-5, Combination Sink, Glass Filler	C	2:20 PM	5	ND	Y	First Draw, Filtered.
Allen-62	Hallway, Outside C-12, Hydration Station, Bottle Fill	HS	1:46 PM	5	ND	Y	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb