



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Angell Elementary School							
Date of Sampling: January 22, 2022							
Sampler: Sabrina Fouche							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Angell-02	Room C-147, Combination Sink, Glass Filler	C	5:28 PM	5	11	N	First Draw, Filtered.
Angell-06	Room C-123, Combination Sink, Glass Filler	C	5:05 PM	5	ND ³	N	First Draw, Filtered.
Angell-09	Room C-217, Combination Sink, Glass Filler	C	4:59 PM	5	ND	N	First Draw, Filtered.
Angell-12	Room C-101, Combination Sink, Glass Filler	C	5:16 PM	5	ND	N	First Draw, Filtered.
Angell-18	Room C-108, Combination Sink, Glass Filler	C	5:08 PM	5	ND	N	First Draw, Filtered.
Angell-23	Room C-145, Combination Sink, Glass Filler	C	5:12 PM	5	ND	N	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb



Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030

Angell Elementary School							
Date of Sampling: January 22, 2022							
Sampler: Sabrina Fouche							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Angell-32	Room C-219, Combination Sink, Glass Filler	C	4:55 PM	5	ND	N	First Draw, Filtered.
Angell-39	Main Office, Combination Sink, Glass Filler	C	5:20 PM	5	ND	N	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb