



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE220030**

Clague Middle School							
Date of Sampling: January 22, 2022							
Sampler: Sabrina Fouche							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Clague-01	Main Entrance/Lobby, Refridgerated, Glass Filler	WC	9:34 AM	5	ND <sup>3</sup>	Y	First Draw, Filtered.
Clague-06	Hallway Outside Pool, Refridgerated, Glass Filler	WC	9:15 AM	5	ND	Y	First Draw, Filtered.
Clague-15	Room 223, Music Room, Combination Sink, Glass Filler	C	9:49 AM	5	ND	Y	First Draw, Filtered.
Clague-20	Room 229, Combination Sink, Glass Filler	C	9:41 AM	5	ND	Y	First Draw, Filtered.
Clague-25	Hallway, Outside Room 208, Refridgerated, Glass Filler	WC	9:45 AM	5	ND	Y	First Draw, Filtered.
Clague-34	Girl's Locker Room, Refridgerated, Glass Filler	WC	9:54 AM	5	ND	Y	First Draw, Filtered.
Clague-37	Kitchen, Singular Central Sink, Combination Sink, Glass Filler	C	9:21 AM	5	ND	Y	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE220030**

Clague Middle School							
Date of Sampling: January 22, 2022							
Sampler: Sabrina Fouche							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Clague-39	Pool, South Wall, Left Stainless, Glass Filler	GF	9:09 AM	5	ND	N	First Draw, Filtered.
Clague-42	"Blue House" Room, West of Room 136, Combination Sink, Glass Filler	C	9:26 AM	5	ND	Y	First Draw, Filtered.
Clague-45	Hallway, Outside Room 124, Refridgerated, Glass Filler	WC	9:29 AM	5	ND	Y	First Draw, Filtered.
Clague-53	Room 142, First Sink, Closest to the Entry, Combination Sink, Glass Filler	C	9:37 AM	5	ND	Y	First Draw, Filtered.
Clague-59	Hallway, Outside Main Offices, Hydration Station, Bottle Fill	HS	9:32 AM	5	ND	Y	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb