



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Dicken Elementary School							
Date of Sampling: January 29, 2022							
Sampler: Victoria Vo							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Dicken-09	Room 113, Left Combination Sink, Glass Filler	C	11:32 AM	5	ND ³	N	First Draw, Filtered.
Dicken-13	Room 122, Combination Sink, Glass Filler	C	11:13 AM	5	ND	N	First Draw, Filtered.
Dicken-16	Room 116, Combination Sink, Glass Filler	C	11:06 AM	5	ND	N	First Draw, Filtered.
Dicken-18	Room 117, Combination Sink, Glass Filler	C	11:10 AM	5	ND	N	First Draw, Filtered.
Dicken-20	Room 104, Combination Sink, Glass Filler	C	11:22 AM	5	ND	N	First Draw, Filtered.
Dicken-29	Room 107, Combination Sink, Glass Filler	C	11:25 AM	5	ND	N	First Draw, Filtered.

- 1) Type: B = Bubblers, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Dicken Elementary School							
Date of Sampling: January 29, 2022							
Sampler: Victoria Vo							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Dicken-35	Room 126, Porcelain, Glass Filler	G	11:19 AM	5	ND	N	First Draw, Filtered.
Dicken-38	Kitchen, 3-Compartment Sink, Add on Faucet, Far Right Kitchen Faucet	KF	10:57 AM	5	ND	Y	First Draw, Filtered.
Dicken-55	Hallway, Outside Room 109, Hydration Station, Bottle Fill	HS	11:28 AM	5	ND	Y	First Draw, Filtered.
Dicken-57	Hallway, Outside Gym, Hydration Station, Bottle Fill	HS	11:03 AM	5	ND	Y	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb