



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE220030**

Eberwhite Elementary School							
Date of Sampling: January 29, 2022							
Sampler: Victoria Vo							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Eberwhite-01	Room 113, Combination Sink, Glass Filler	C	8:31 AM	5	ND <sup>3</sup>	N	First Draw, Filtered.
Eberwhite-10	Hallway, Outside Room 122, Right Stainless Glass Filler	G	8:57 AM	5	ND	N	First Draw, Filtered.
Eberwhite-11	Hallway, Outside Main Office, Hydration Station, Bottle Fill	HS	8:40 AM	5	ND	Y	First Draw, Filtered.
Eberwhite-14	Room 135, Combination Sink, Glass Filler	C	9:13 AM	5	ND	N	First Draw, Filtered.
Eberwhite-17	Kitchen, 1-Compartment Sink, Kitchen Faucet	KF	8:35 AM	5	13	Y	First Draw, Filtered.
Eberwhite-21	Room 129, Combination Sink, Glass Filler	C	9:00 AM	5	ND	N	First Draw, Filtered.

- 1) Type: B = Bubblers, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE220030**

<b>Eberwhite Elementary School</b>							
<b>Date of Sampling: January 29, 2022</b>							
<b>Sampler: Victoria Vo</b>							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Eberwhite-25	Room 126, Combination Sink, Glass Filler	C	9:03 AM	5	ND	N	First Draw, Filtered.
Eberwhite-29	Room 132, Combination Sink, Glass Filler	C	9:17 AM	5	ND	N	First Draw, Filtered.
Eberwhite-33	Room 114, Combination Sink, Glass Filler	C	8:44 AM	5	ND	N	First Draw, Filtered.
Eberwhite-35	Room 112, Combination Sink, Glass Filler	C	8:48 AM	5	ND	N	First Draw, Filtered.
Eberwhite-41	Room 108, Combination Sink, Glass Filler	C	8:52 AM	5	ND	N	First Draw, Filtered.

- 1) Type: B = Bubblers, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb