



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE220030**

Haisley Elementary School							
Date of Sampling: February 5, 2022							
Sampler: Zachary Fortin							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Haisley-05	Room 112, Combination Sink, Glass Filler	C	1:17 PM	5	ND <sup>3</sup>	N	First Draw, Filtered.
Haisley-12	Main Office Back Lounge, Combination Sink, Glass Filler	C	1:09 PM	5	ND	N	First Draw, Filtered.
Haisley-22	Room 101, Combination Sink, Glass Filler	C	1:35 PM	5	ND	N	First Draw, Filtered.
Haisley-26	Room 104, Combination Sink, Glass Filler	C	1:28 PM	5	ND	N	First Draw, Filtered.
Haisley-35	Multi-Purpose Room, Hydration Station, Bottle Fill	HS	1:42 PM	5	ND	Y	First Draw, Filtered.
Haisley-38	Room 202, Combination Sink, Glass Filler	C	2:00 PM	5	ND	N	First Draw, Filtered.

- 1) Type: B = Bubblers, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE220030**

Haisley Elementary School							
Date of Sampling: February 5, 2022							
Sampler: Zachary Fortin							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Haisley-39	Room 145, Combination Sink, Glass Filler	C	1:51 PM	5	ND	Y	First Draw, Filtered.
Haisley-42	Room 206, Combination Sink, Glass Filler	C	2:08 PM	5	ND	N	First Draw, Filtered.
Haisley-50	Room 406, Combination Sink, Glass Filler	C	2:13 PM	5	ND	N	First Draw, Filtered.
Haisley-55	Room 302, Combination Sink, Glass Filler	C	2:18 PM	5	ND	N	First Draw, Filtered.
Haisley-60	Room 307, Combination Sink, Glass Filler	C	2:24 PM	5	ND	N	First Draw, Filtered.
Haisley-69	Hallway, Outside Room 108, Hydration Station, Bottle Fill	HS	1:23 PM	5	ND	Y	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb