



Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE220030

Huron High School							
Date of Sampling: February 16, 2022							
Sampler: Zachary Fortin							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Huron-29A	Kitchen, Plumbed Coffee Machine	PC	7:55 PM	5	15	N	First Draw Following Filter Installation. Location Removed from Service and Supply Line Capped. No Further Action Needed.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb