



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

| King Elementary School | | | | | | | |
|------------------------------------|--|-------------------|----------------|------------------------------|---------------------|---------------------|-----------------------|
| Date of Sampling: January 22, 2022 | | | | | | | |
| Sampler: Sabrina Fouche | | | | | | | |
| Sample # | Location | Type ¹ | Time Collected | Internal Action Level (ug/L) | Lead Results (ug/L) | Aerator Present Y/N | Notes |
| King-02 | Psychology and Social Work Room, Faucet | F | 1:32 PM | 5 | ND ³ | Y | First Draw, Filtered. |
| King-06 | Room 107, Combination Sink, Glass Filler | C | 1:49 PM | 5 | ND | Y | First Draw, Filtered. |
| King-14 | Main Office, Workroom, Combination Sink, Bottle Fill | C | 1:19 PM | 5 | ND | Y | First Draw, Filtered. |
| King-19 | Kitchen, 3-Compartment Sink, Add On Faucet, Far Left, Combination Sink, Glass Filler | KF | 1:37 PM | 5 | ND | Y | First Draw, Filtered. |
| King-23 | Room KI-K2, Combination Sink, Glass Filler | C | 1:41 PM | 5 | ND | Y | First Draw, Filtered. |
| King-30 | Room 111, Combination Sink, Glass Filler | C | 1:52 PM | 5 | ND | Y | First Draw, Filtered. |
| King-36 | Room 114, Combination Sink, Glass Filler | C | 1:59 PM | 5 | ND | Y | First Draw, Filtered. |
| King-42 | Room 117, Combination Sink, Glass Filler | C | 2:03 PM | 5 | ND | Y | First Draw, Filtered. |

- 1) Type: B = Bubblers, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

| King Elementary School | | | | | | | |
|------------------------------------|---|-------------------|----------------|------------------------------|---------------------|---------------------|-----------------------|
| Date of Sampling: January 22, 2022 | | | | | | | |
| Sampler: Sabrina Fouche | | | | | | | |
| Sample # | Location | Type ¹ | Time Collected | Internal Action Level (ug/L) | Lead Results (ug/L) | Aerator Present Y/N | Notes |
| King-49 | Room 103, Combination Sink, Glass Filler | C | 2:06 PM | 5 | ND | Y | First Draw, Filtered. |
| King-56 | Learning Center, Combination Sink, Glass Filler | C | 1:55 PM | 5 | ND | Y | First Draw, Filtered. |
| King-59 | Hallway, Outside Room C-107, Hydration Station, Bottle Fill | HS | 1:44 PM | 5 | ND | Y | First Draw, Filtered. |

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb