



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Lawton Elementary School							
Date of Sampling: January 29, 2022							
Sampler: Victoria Vo							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Lawton-07	Kitchen, 3-Compartment Sink, Add On Faucet, Far Right Kitchen Faucet	KF	4:47 PM	5	ND ³	Yes	First Draw, Filtered.
Lawton-10	Room 203, Combination Sink, Glass Filler	C	4:51 PM	5	ND	No	First Draw, Filtered.
Lawton-14	Room 314, Combination Sink, Glass Filler	C	4:27 PM	5	ND	No	First Draw, Filtered.
Lawton-18	Room 304, Combination Sink, Glass Filler	C	4:37 PM	5	ND	No	First Draw, Filtered.
Lawton-23	Room 209, Combination Sink, Glass Filler	C	4:41 PM	5	ND	No	First Draw, Filtered.
Lawton-27	Room 311, Combination Sink, Glass Filler	C	4:31 PM	5	ND	No	First Draw, Filtered.

- 1) Type: B = Bubblers, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Lawton Elementary School							
Date of Sampling: January 29, 2022							
Sampler: Victoria Vo							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Lawton-33	Room 102, Combination Sink, Glass Filler	C	5:08 PM	5	ND	No	First Draw, Filtered.
Lawton-37	Hallway Outside Room 114, Hydration Station, Bottle Fill	HS	4:23 PM	5	ND	Yes	First Draw, Filtered.
Lawton-42	Room 107, Combination Sink, Glass Filler	C	4:20 PM	5	ND	No	First Draw, Filtered.
Lawton-65	Room 218, Staff Lounge, Combination Sink, Glass Filler	C	5:04 PM	5	ND	No	First Draw, Filtered.
Lawton-66	Hallway Outside Room 301, Hydration Station, Bottle Fill	HS	4:33 PM	5	ND	Yes	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb