



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Logan Elementary School							
Date of Sampling: January 22, 2022							
Sampler: Sabrina Fouche							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Logan ES-02	Teacher's Lounge, Combination Sink, Glass Filler	C	8:13 AM	5	ND ³	Yes	First Draw, Filtered.
Logan ES-07	Room 324, Combination Sink, Glass Filler	C	8:02 AM	5	ND	Yes	First Draw, Filtered.
Logan ES-14	Room 326, Combination Sink, Glass Filler	C	7:59 AM	5	ND	Yes	First Draw, Filtered.
Logan ES-22	Room 333, Combination Sink, Glass Filler	C	7:55 AM	5	ND	Yes	First Draw, Filtered.
Logan ES-29	Room 224, Combination Sink, Glass Filler	C	8:22 AM	5	ND	Yes	First Draw, Filtered.
Logan ES-36	Room 236, Combination Sink, Glass Filler	C	8:17 AM	5	ND	Yes	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Logan Elementary School							
Date of Sampling: January 22, 2022							
Sampler: Sabrina Fouche							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Logan ES-41	Room 241, Combination Sink, Glass Filler	C	8:19 AM	5	ND	Yes	First Draw, Filtered.
Logan ES-49	Kitchen, 3-Compartment Sink, Add On, Far Right, Glass Filler	KF	8:06 AM	5	ND	Yes	First Draw, Filtered.
Logan ES-51	Media Center, Outside Room C-324, Hydration Station, Bottle Fill	HS	8:32 AM	5	ND	Yes	First Draw, Filtered.
Logan ES-55	Multi-Use/Cafeteria, Small Outside Kitchen Door, Hydration Station, Bottle Fill	HS	8:09 AM	5	ND	Yes	First Draw, Filtered.

- 1) Type: B = Bubblers, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb