



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Mitchell Elementary School							
Date of Sampling: January 29, 2022							
Sampler: Sabrina Fouche							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Mitchell-02	Room 3, Combination Sink, Glass Filler	C	4:00 PM	5	ND ³	Y	First Draw, Filtered.
Mitchell-06	Room 8, Combination Sink, Glass Filler	C	3:47 PM	5	ND	Y	First Draw, Filtered.
Mitchell-18	Room 5, Combination Sink, Glass Filler	C	3:57 PM	5	ND	Y	First Draw, Filtered.
Mitchell-26	Room 1, Combination Sink, Right Sink, Glass Filler	C	3:52 PM	5	ND	Y	First Draw, Filtered.
Mitchell-36	Room 6, Combination Sink, Left Sink, Glass Filler	C	3:55 PM	5	ND	Y	First Draw, Filtered.
Mitchell-43	Room 10, Combination Sink, Left Sink, Glass Filler	C	3:51 PM	5	ND	Y	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Mitchell Elementary School							
Date of Sampling: January 29, 2022							
Sampler: Sabrina Fouche							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Mitchell-52	Room 20, Combination Sink, Glass Filler	C	4:02 PM	5	ND	Y	First Draw, Filtered.
Mitchell-65	Room 26, Combination Sink, Glass Filler	C	4:02 PM	5	ND	Y	First Draw, Filtered.
Mitchell-70	Room 24, Combination Sink, Glass Filler	C	4:04 PM	5	ND	Y	First Draw, Filtered.
Mitchell-57	Kitchen, 3-Compartment Sink, Far Left, Faucet	C	4:17 PM	5	ND	Y	First Draw, Filtered.
Mitchell-78	Hallway, Outside Art Room, Hydration Station, Bottle Fill	HS	3:57 PM	5	ND	Y	First Draw, Filtered.
Mitchell-17	Hallway, Outside Gym, Hydration Station, Bottle Fill	HS	4:17 PM	5	ND	Y	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb



Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030

Mitchell Elementary School							
Date of Sampling: January 29, 2022							
Sampler: Sabrina Fouche							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Mitchell-49	Room 16, Combination Sink, Glass Filler	C	4:21 PM	5	ND	Y	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb