



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Pathways to Success							
Date of Sampling: March 5, 2022							
Sampler: Zac Fortin							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pathways-01	Room 113, Left Combination Sink, Glass Filler	C	12:19 PM	5	ND ³	N	First Draw, Filtered.
Pathways-07	Hallway, Between Men's and Women's Bathroom, Glass Filler	GF	12:11 PM	5	ND	N	First Draw, Filtered.
Pathways-11	Kitchen, 3-Compartment Sink, Single Add on Faucet, Far Right	KF	12:07 PM	5	ND	Y	First Draw, Filtered.
Pathways-18	Hallway, Outside Room 402, Hydration Station, Bottle Fill	HS	12:00 PM	5	ND	Y	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb