



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE220030**

**Pioneer High School**

**Date of Sampling: January 29, 2022**

**Sampler: Victoria Vo**

Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pioneer-05	Hallway, Right of Auditorium, Hydration Station, Bottle Fill	HS	1:36 PM	5	ND <sup>3</sup>	Y	First Draw, Filtered.
Pioneer-16	Main Gym, Near South Entrance, Left Wall Glass Filler	G	2:04 PM	5	ND	N	First Draw, Filtered.
Pioneer-17	Pool Deck, By Diving Board, Porcelain Glass Filler on West Wall	G	2:30 PM	5	ND	N	First Draw, Filtered.
Pioneer-20	Auxiliary Gym, Outside Girl's Locker Room, Wall Glass Filler	G	2:19 PM	5	ND	N	First Draw, Filtered.
Pioneer-21	Boy's Auxiliary Gym Locker Room, Stainless, Glass Filler	G	2:39 PM	5	ND	N	First Draw, Filtered.
Pioneer-01	Hallway, B-Wing, Outside Room B-126A, Refrigerated Glass Filler	G	1:26 PM	5	ND	N	First Draw, Filtered.
Pioneer-28	Football Coach Office, Next to Receiving, Combination Sink, Glass Filler	C	2:12 PM	5	ND	N	First Draw, Filtered.

- 1) Type: B = Bubblers, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE220030**

**Pioneer High School**

**Date of Sampling: January 29, 2022**

**Sampler: Victoria Vo**

Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pioneer-29	Main Office Suite, Infirmary S-174, Second Combination Sink, Glass Filler	C	1:12 PM	5	ND	N	First Draw, Filtered.
Pioneer-32	Hallway, Main Office Suite, Refrigerated Glass Filler	G	1:04 PM	5	ND	N	First Draw, Filtered.
Pioneer-38	Hallway, Outside, C-121, Hydration Station, Bottle Fill	HS	12:38 PM	5	ND	Y	First Draw, Filtered.
Pioneer-41	Kitchen, Ice Machine	I	12:49 PM	5	ND	N	First Draw, Filtered.
Pioneer-42	Cafeteria, Outside Teachers Lounge, Hydration Station, Bottle Fill	HS	12:54 PM	5	ND	Y	First Draw, Filtered.
Pioneer-46	Hallway, Outside Room C-110, Hydration Station, Bottle Fill	HS	12:59 PM	5	ND	Y	First Draw, Filtered.
Pioneer-49	Hallway, Outside Room E-101, Refrigerated Glass Filler	G	12:27 PM	5	ND	N	First Draw, Filtered.

- 1) Type: B = Bubblers, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE220030**

**Pioneer High School**

**Date of Sampling: January 29, 2022**

**Sampler: Victoria Vo**

Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pioneer-54	Hallway, Outside Room E-112, Left Hydration Station, Bottle Fill	HS	12:32 PM	5	ND	Y	First Draw, Filtered.
Pioneer-58	Lower Level Track/Weight Room, Hydration Station, Bottle Fill	HS	1:49 PM	5	ND	Y	First Draw, Filtered.
Pioneer-60	Hallway, Outside Room C-206, Hydration Station, Bottle Fill	HS	12:19 PM	5	ND	Y	First Draw, Filtered.
Pioneer-68	Hallway, Outside Room D-213, Hydration Station, Bottle Fill	HS	12:23 PM	5	ND	Y	First Draw, Filtered.
Pioneer-71	Hallway, Outside Room C-310, Hydration Station, Bottle Fill	HS	12:15 PM	5	ND	Y	First Draw, Filtered.
Pioneer-85	Kitchen, Left Plumbed Coffee Machine	PC	12:42 PM	5	6	Y	First Draw, Filtered.
Pioneer-03	Main Gym, Near South Entrance, Right Wall Glass Filler	G	2:05 PM	5	ND	N	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb