



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Pittsfield Elementary School							
Date of Sampling: January 29, 2022							
Sampler: Sabrina Fouche							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pittsfield-02	Staff Lounge, Kitchen Faucet, Glass Filler	GF	2:49 PM	5	ND ³	Y	First Draw, Filtered.
Pittsfield-07	Room 101, Combination Sink, Glass Filler	C	3:08 PM	5	ND	Y	First Draw, Filtered.
Pittsfield-10	Room 107, Combination Sink, Glass Filler	C	2:58 PM	5	ND	Y	First Draw, Filtered.
Pittsfield-13	Hallway Outside Gym, Hydration Station, Bottle Fill	HS	2:56 PM	5	ND	Y	First Draw, Filtered.
Pittsfield-25	Room 102, Combination Sink, Glass Filler	C	2:56 PM	5	ND	Y	First Draw, Filtered.
Pittsfield-31	Room 112, Combination Sink, Glass Filler	C	3:10 PM	5	ND	Y	First Draw, Filtered.
Pittsfield-37	Kitchen, 3-Compartment Sink, Add On Faucet, Far Right	KF	3:13 PM	5	ND	Y	First Draw, Filtered.
Pittsfield-39	Media Center, Combination Sink, Glass Filler	C	3:08 PM	5	ND	Y	First Draw, Filtered.

- 1) Type: B = Bubblers, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb