



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Scarlett Middle School							
Date of Sampling: March 12, 2022							
Sampler: Zachary Fortin							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Scarlett-02	Girl's Locker Room, Porcelain, Glass Filler	GF	8:41 AM	5	ND ³	N	First Draw, Filtered.
Scarlett-07	Pool, Outside Girls Locker Room, Glass Filler	GF	8:52 AM	5	ND	N	First Draw, Filtered.
Scarlett-11	Kitchen, South Wall, Combination Sink, Glass Filler	C	9:07 AM	5	ND	N	First Draw, Filtered.
Scarlett-14	Room 137, Combination Sink, Glass Filler	C	9:21 AM	5	ND	N	First Draw, Filtered.
Scarlett-17	Room 201, Combination Sink, Glass Filler	C	9:38 AM	5	ND	N	First Draw, Filtered.
Scarlett-27	Hallway, Outside of Room 124, Hydration Station, Bottle Fill	HS	9:14 AM	5	ND	Y	First Draw, Filtered.
Scarlett-31	Hallway, Outside Room 205, Single Bottle Fill	BT	9:45 AM	5	ND	N	First Draw, Filtered.
Scarlett-32	Pool, Outside Boys Locker Room, Right Bottle Fill	BT	8:48 AM	5	ND	N	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb



Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030

Scarlett Middle School							
Date of Sampling: March 12, 2022							
Sampler: Zachary Fortin							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Scarlett-36	RAHS Clinic Office, Combination Sink, Glass Filler	C	9:32 AM	5	ND	N	First Draw, Filtered.
Scarlett-37	Kitchen Area, Kitchen Kettle	KK	9:02 AM	5	2	N	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb