



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Skyline High School							
Date of Sampling: January 22, 2022							
Sampler: Victoria Vo							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Skyline-02	Room C104, Choir Room, Left Porcelain Glass Filler	G	2:04 PM	5	ND ³	N	First Draw, Filtered.
Skyline-05	Main Office Suite, Room A204-D, Combination Sink, Glass Filler	C	12:01 PM	5	ND	N	First Draw, Filtered.
Skyline-07	Room C116, Left Porcelain Glass Filler	G	2:00 PM	5	ND	N	First Draw, Filtered.
Skyline-15	Girl's Locker Room for Pool, Left Refrigerated Glass Filler	G	1:53 PM	5	ND	N	First Draw, Filtered.
Skyline-27	Auxiliary Gym, North Wall, Single Bottle Fill	BT	1:40 PM	5	ND	Y	First Draw, Filtered.
Skyline-38	Hallway, Floor 1, Outside Room A119, Hydration Station, Bottle Fill	HS	1:49 PM	5	ND	Y	First Draw, Filtered.

- 1) Type: B = Bubblers, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Skyline High School							
Date of Sampling: January 22, 2022							
Sampler: Victoria Vo							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Skyline-66	Hallway, Floor 2, Outside C-214 & C-217 Men's Restroom, Single Bottle Fill	BT	12:18 PM	5	ND	Y	First Draw, Filtered.
Skyline-45	Kitchen, Central Island, Double Compartment Sink, Kitchen Faucet	C	12:28 PM	5	ND	Y	First Draw, Filtered.
Skyline-48	Room A303a, Combination Sink, Glass Filler	C	2:16 PM	5	ND	N	First Draw, Filtered.
Skyline-54	Hallway, Floor 3, Near Media Center, Outside Room B-331, Single Bottle Fill	BT	12:39 PM	5	ND	Y	First Draw, Filtered.
Skyline-55	Room B308, Sink, Faucet	F	12:35 PM	5	ND	Y	First Draw, Filtered.
Skyline-56	Room C303-A, Combination Sink, Glass Filler	C	1:12 PM	5	ND	Y	First Draw, Filtered.

- 1) Type: B = Bubblers, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Skyline High School							
Date of Sampling: January 22, 2022							
Sampler: Victoria Vo							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Skyline-57	Room A403-A, Combination Sink, Glass Filler	C	2:20 PM	5	ND	N	First Draw, Filtered.
Skyline-63	Hallway, Floor 4, Outside Room B-431, Single Bottle Fill	BT	1:20 PM	5	ND	N	First Draw, Filtered.
Skyline-70	Hallway, Floor 2, Outside A-227 Track & Men's Restroom, Single Bottle Fill	BT	12:10 PM	5	ND	Y	First Draw, Filtered.
Skyline-72	Main Gym, South End, Single Bottle Fill	BT	1:45 PM	5	ND	Y	First Draw, Filtered.
Skyline-09	Hallway, Floor 3, Near Media Center, Outside Room B-331, Refrigerated Glass Filler	G	12:47 PM	5	ND	N	First Draw, Filtered.
Skyline-11	Hallway, Floor 3, Near Media Center, Outside Room B-325, Refrigerated Glass Filler	G	1:05 PM	5	ND	N	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Skyline High School							
Date of Sampling: January 22, 2022							
Sampler: Victoria Vo							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Skyline-17	Hallway, Floor 4, Outside Room B-431, Refrigerated Glass Filler	G	1:25 PM	5	ND	N	First Draw, Filtered.
Skyline-18	Hallway, Floor 4, Outside Room B-425, Refrigerated Glass Filler	G	1:21 PM	5	ND	N	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb