



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Slauson Middle School							
Date of Sampling: February 5, 2022							
Sampler: Zachary Fortin							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Slauson-04	Hallway, Outside of Room 146, Hydration Station, Bottle Fill	HS	6:06 PM	5	ND ³	Y	First Draw, Filtered.
Slauson-05	Girls Gym Locker Room, Stainless Glass Filler	G	6:00 PM	5	ND	N	First Draw, Filtered.
Slauson-14	Women's Pool Locker Room, Refrigerated Glass Filler	G	6:20 PM	5	ND	N	First Draw, Filtered.
Slauson-17	Library Lounge, Kitchen Faucet	KF	6:31 PM	5	ND	N	First Draw, Filtered.
Slauson-24	Auditorium Lobby, Hydration Station, Bottle Fill	HS	6:41 PM	5	ND	Y	First Draw, Filtered.
Slauson-27	Hallway, Outside Room 203, Refrigerated Glass Filler	G	6:53 PM	5	ND	N	First Draw, Filtered.
Slauson-29	Room 346, Combination Sink, Glass Filler	C	7:09 PM	5	ND	N	First Draw, Filtered.

- 1) Type: B = Bubblers, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Slauson Middle School							
Date of Sampling: February 5, 2022							
Sampler: Zachary Fortin							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Slauson-31	Computer Room, Rooms 300 & 300A, Combination Sink, Bottle Fill	C	7:03 PM	5	ND	N	First Draw, Filtered.
Slauson-35	Kitchen, 3-Compartment, Far Right Add On Single Faucet, Kitchen Faucet	KF	6:13 PM	5	ND	Y	First Draw, Filtered.
Slauson-48	Hallway, Outside Room 303, Hydration Station, Bottle Fill	HS	6:59 PM	5	ND	Y	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb