



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Thurston Elementary School							
Date of Sampling: January 22, 2022							
Sampler: Sabrina Fouche							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Thurston-02	Lounge, Kitchen, Combination Sink, Glass Filler	C	10:16 AM	5	ND ³	Yes	First Draw, Filtered.
Thurston-08	Room 3, Combination Sink, Glass Filler	C	10:44 AM	5	ND	Yes	First Draw, Filtered.
Thurston-13	Room 28, Combination Sink, Glass Filler	C	10:39 AM	5	ND	Yes	First Draw, Filtered.
Thurston-19	Room 22, Combination Sink, Glass Filler	C	10:33 AM	5	ND	Yes	First Draw, Filtered.
Thurston-25	Room 23, Combination Sink, Glass Filler	C	10:36 AM	5	ND	Yes	First Draw, Filtered.
Thurston-30	Room 7, Combination Sink, Glass Filler	C	10:21 AM	5	ND	Yes	First Draw, Filtered.
Thurston-35	Room A101, Combination Sink, Glass Filler	C	10:28 AM	5	ND	Yes	First Draw, Filtered.
Thurston-43	Main Office Kitchenette, Combination Sink, Glass Filler	C	10:50 AM	5	ND	Yes	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Thurston Elementary School							
Date of Sampling: January 22, 2022							
Sampler: Sabrina Fouche							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Thurston-55	Kitchen, Three-Compartment Sink, Single Add on, Far Left, Glass Filler	KF	10:47 AM	5	ND	Yes	First Draw, Filtered.
Thurston-62	Hallway, in Front of Custodian Lounge, Hydration Station, Bottle Fill	HS	10:19 AM	5	ND	Yes	First Draw, Filtered.
Thurston-65	Hallway, Outside Room K12, Hydration Station, Bottle Fill	HS	10:23 AM	5	ND	Yes	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb