



**Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE230030**

| Abbot Elementary School | | | | | | | | | |
|------------------------------------------|----------------------------------------------------------------------------|-------------------|----------------|------------------------------------------------|---------------------|---------------------|------------------------|-------------------|-------------------------------|
| Date of Sampling: January 3, 2023 | | | | | | | | | |
| Sampler: Victoria Heed | | | | | | | | | |
| Sample # | Location | Type ¹ | Time Collected | District Lead Action Level (ug/L) ² | Lead Results (ug/L) | Aerator Present Y/N | POU Filter Present Y/N | Filter Date/Color | Notes |
| Abbot-07 | Child Care Room B-1, Combination Sink, Glass Filler | C | 1:03 PM | 5 | ND ³ | N | Y | 6/13/2022 | Initial First Draw, Filtered. |
| Abbot-09 | Room D-3, Stainless Glass Filler | G | 1:27 PM | 5 | ND | N | Y | 6/14/2022 | Initial First Draw, Filtered. |
| Abbot-13 | Hall, Next to Gym, Across Teacher's Lounge, Hydration Station, Bottle Fill | HS | 12:56 PM | 5 | ND | Y | Y | No Filter Light | Initial First Draw, Filtered. |
| Abbot-15 | Room D-6, Island Near Door, Combination Sink, Glass Filler | C | 1:23 PM | 5 | ND | N | Y | 6/14/2022 | Initial First Draw, Filtered. |
| Abbot-24 | Room C-6, Stainless Glass Filler | G | 1:18 PM | 5 | ND | N | N | 6/14/2022 | Initial First Draw, Filtered. |

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



**Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE230030**

| Abbot Elementary School | | | | | | | | | |
|------------------------------------------|---------------------------------------------------------------|-------------------|----------------|------------------------------------------------|---------------------|---------------------|------------------------|-------------------|-------------------------------|
| Date of Sampling: January 3, 2023 | | | | | | | | | |
| Sampler: Victoria Heed | | | | | | | | | |
| Sample # | Location | Type ¹ | Time Collected | District Lead Action Level (ug/L) ² | Lead Results (ug/L) | Aerator Present Y/N | POU Filter Present Y/N | Filter Date/Color | Notes |
| Abbot-27 | Hallway, Adjacent to Room C-8, Hydration Station, Bottle Fill | HS | 1:14 PM | 5 | ND | Y | Y | Green | Initial First Draw, Filtered. |
| Abbot-34 | Room A-7, Stainless Glass Filler | G | 12:50 PM | 5 | ND | N | Y | 6/13/2022 | Initial First Draw, Filtered. |
| Abbot-37 | Room A-10, Stainless Glass Filler | G | 12:47 PM | 5 | ND | N | Y | 6/13/2022 | Initial First Draw, Filtered. |
| Abbot-41 | Room A-4, Stainless Glass Filler | G | 12:54 PM | 5 | ND | N | Y | 6/13/2022 | Initial First Draw, Filtered. |
| Abbot-45 | Art Room, Combination Sink, Glass Filler | C | 1:08 PM | 5 | ND | N | Y | 6/13/2022 | Initial First Draw, Filtered. |

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L