



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE230030

Allen Elementary School									
Date of Sampling: January 5, 2023									
Sampler: Sabrina Fouche									
Sample #	Location	Type ¹	Time Collected	District Lead Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Allen-03	Room CL-8, Combination Sink, Glass Filler	C	7:52 AM	5	ND ³	N	Y	6/14/22	Initial First Draw, Filtered.
Allen-10	Hall, Outside of Women's Bathroom, By Gym, Refrigerated Glass Filler	G	8:17 AM	5	ND	N	Y	6/13/22	Initial First Draw, Filtered.
Allen-15	Room A-16, Combination Sink, Glass Filler	C	8:14 AM	5	ND	N	Y	6/13/22	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE230030

Allen Elementary School									
Date of Sampling: January 5, 2023									
Sampler: Sabrina Fouche									
Sample #	Location	Type ¹	Time Collected	District Lead Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Allen-19	Room A-15, Combination Sink, Glass Filler	C	8:08 AM	5	ND	N	Y	6/14/22	Initial First Draw, Filtered.
Allen-21	Room A-20, Combination Sink, Glass Filler	C	8:11 AM	5	ND	N	Y	6/13/22	Initial First Draw, Filtered.
Allen-29	Room C-11, Combination Sink, Glass Filler	C	7:44 AM	5	ND	N	Y	6/13/22	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE230030

Allen Elementary School									
Date of Sampling: January 5, 2023									
Sampler: Sabrina Fouche									
Sample #	Location	Type ¹	Time Collected	District Lead Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Allen-34	Hallway, Between Rooms K-3 and K-4, Hydration Station, Bottle Fill	HS	7:56 AM	5	ND	Y	Y	Green	Initial First Draw, Filtered.
Allen-38	Room K-2, Combination Sink, Glass Filler	G	7:59 AM	5	ND	N	Y	6/14/22	Initial First Draw, Filtered.
Allen-47	Room B-24, Combination Sink, Glass Filler	G	8:21 AM	5	ND	N	Y	6/13/22	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE230030

Allen Elementary School									
Date of Sampling: January 5, 2023									
Sampler: Sabrina Fouche									
Sample #	Location	Type ¹	Time Collected	District Lead Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Allen-54	Room CL-7, Combination Sink, Glass Filler	G	7:49 AM	5	ND	N	Y	6/14/22	Initial First Draw, Filtered.
Allen-60	Hallway, Outside A-14, Hydration Station, Bottle Fill	HS	8:04 AM	5	ND	Y	Y	Green	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L