



Ann Arbor Public Schools  
 Drinking Water Analysis  
 Project Number: AE230030

Carpenter Elementary School									
Date of Sampling: January 5, 2023									
Sampler: Sabrina Fouche									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Carpenter-03	Room C-137, Combination Sink, Glass Filler	C	10:30 AM	5	ND <sup>3</sup>	N	Y	6/22/23	Initial First Draw, Filtered.
Carpenter-08	Room C-112, Combination Sink, Glass Filler	C	10:17 AM	5	ND	N	Y	6/21/22	Initial First Draw, Filtered.
Carpenter-10	Room C-120, Combination Sink, Glass Filler	C	10:01 AM	5	ND	N	Y	6/21/22	Initial First Draw, Filtered.
Carpenter-16	Room C-114, Combination Sink, Glass Filler	C	10:08 AM	5	ND	N	Y	6/21/22	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools  
 Drinking Water Analysis  
 Project Number: AE230030

Carpenter Elementary School									
Date of Sampling: January 5, 2023									
Sampler: Sabrina Fouche									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Carpenter-25	Room C-115, Combination Sink, Glass Filler	C	10:13 AM	5	ND	N	Y	6/21/22	Initial First Draw, Filtered.
Carpenter-31	Room C-121, Combination Sink, Glass Filler	C	9:58 AM	5	ND	N	Y	6/21/22	Initial First Draw, Filtered.
Carpenter-35	Kitchen, 3-Compartment Sink, Right Food Prep Faucet, Kitchen Faucet	KF	9:53 AM	5	ND	Y	Y	8/10/21	Initial First Draw, Filtered.
Carpenter-40	Room C-142, Combination Sink, Glass Filler	C	10:34 AM	5	ND	N	Y	6/22/22	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools  
 Drinking Water Analysis  
 Project Number: AE230030

Carpenter Elementary School									
Date of Sampling: January 5, 2023									
Sampler: Sabrina Fouche									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Carpenter-46	Gymnasium, Single Bottle Fill	BT	10:23 AM	5	ND	N	Y	6/22/22	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L