



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE230030

Dicken Elementary School

Date of Sampling: January 4, 2023

Sampler: Victoria Heed

Sample #	Location	Type ¹	Time Collected	District Lead Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Dicken-07	Room 114, Right Combination Sink, Glass Filler	C	12:04 PM	5	ND ³	N	Y	6/23/2022	Initial First Draw, Filtered.
Dicken-15	Room 118, Combination Sink, Glass Filler	C	12:29 PM	5	ND	N	Y	7/12/2022	Initial First Draw, Filtered.
Dicken-21	Room 106, Combination Sink, Glass Filler	C	11:56 AM	5	ND	N	Y	6/24/2022	Initial First Draw, Filtered.
Dicken-23	Room 110, Combination Sink, Glass Filler	C	11:59 AM	5	ND	N	Y	6/23/2022	Initial First Draw, Filtered.
Dicken-27	Room 111, Combination Sink, Glass Filler	C	12:10 PM	5	ND	N	Y	6/23/2022	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE230030

Dicken Elementary School									
Date of Sampling: January 4, 2023									
Sampler: Victoria Heed									
Sample #	Location	Type ¹	Time Collected	District Lead Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Dicken-31	Room 103, Combination Sink, Glass Filler	C	12:18 PM	5	ND	N	Y	6/24/2022	Initial First Draw, Filtered.
Dicken-17	Room 119, Combination Sink, Glass Filler	C	12:33 PM	5	ND	N	Y	7/12/2022	Initial First Draw, Filtered.
Dicken-34	Room 128, Combination Sink, Glass Filler	C	12:26 PM	5	ND	N	Y	6/24/2022	Initial First Draw, Filtered.
Dicken-36	Gym, Wall Glass Filler	G	12:23 PM	5	ND	N	Y	Filter Behind Wall	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L