



**Ann Arbor Public Schools  
Drinking Water Analysis  
Project Number: AE230030**

<b>Haisley Elementary School</b>									
<b>Date of Sampling: January 3, 2023</b>									
<b>Sampler: Victoria Heed</b>									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Haisley-02	Hallway, Across from Room 200, Hydration Station, Bottle Fill	HS	2:22 PM	5	ND <sup>3</sup>	Y	Y	No Filter Light	Initial First Draw, Filtered.
Haisley-03	Room 200, Combination Sink, Glass Filler	C	2:26 PM	5	ND	N	Y	7/5/2022	Initial First Draw, Filtered.
Haisley-07	Main Office, Clinic, Combination Sink, Glass Filler	C	2:05 PM	5	ND	N	Y	7/5/2022	Initial First Draw, Filtered.
Haisley-11	Room 102, Combination Sink, Glass Filler	C	2:16 PM	5	ND	N	Y	7/5/2022	Initial First Draw, Filtered.
Haisley-20	Room 103, Combination Sink, Glass Filler	C	2:19 PM	5	ND	N	Y	7/5/2022	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



**Ann Arbor Public Schools  
Drinking Water Analysis  
Project Number: AE230030**

<b>Haisley Elementary School</b>									
<b>Date of Sampling: January 3, 2023</b>									
<b>Sampler: Victoria Heed</b>									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Haisley-28	Room 108, Combination Sink, Glass Filler	C	2:13 PM	5	ND	N	Y	7/5/2022	Initial First Draw, Filtered.
Haisley-32	Kitchen, 3-Compartment Sink, Single Add on, Glass Filler	G	2:09 PM	5	ND	N	Y	7/5/2022	Initial First Draw, Filtered.
Haisley-44	Room 400, Combination Sink, Glass Filler	C	2:32 PM	5	ND	N	Y	7/1/2022	Initial First Draw, Filtered.
Haisley-48	Room 404, Combination Sink, Glass Filler	C	2:29 PM	5	ND	N	Y	7/1/2022	Initial First Draw, Filtered.
Haisley-57	Room 304, Combination Sink, Glass Filler	C	2:42 PM	5	ND	N	Y	7/5/2022	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools  
 Drinking Water Analysis  
 Project Number: AE230030

Haisley Elementary School									
Date of Sampling: January 3, 2023									
Sampler: Victoria Heed									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Haisley-62	Room 305, Combination Sink, Glass Filler	C	2:39 PM	5	ND	N	Y	7/6/2022	Initial First Draw, Filtered.
Haisley-64	Hallway, Outside Room 302, Hydration Station, Bottle Fill	HS	2:35 PM	5	ND	Y	Y	Green	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L