



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE230030

King Elementary School									
Date of Sampling: January 4, 2023									
Sampler: Sabrina Fouche									
Sample #	Location	Type ¹	Time Collected	District Lead Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
King -05	Room 106, Combination Sink, Glass Filler	C	8:42 AM	5	ND ³	N	Y	6/23/22	Initial First Draw
King-11	Room 108, Combination Sink, Glass Filler	C	8:53 AM	5	ND	N	Y	6/23/2022	Initial First Draw, Filtered
King-13	Hallway, Outside of Room 113, Hydration Station, Bottle Fill	HS	9:00 AM	5	ND	Y	Y	Green	Initial First Draw, Filtered.
King-17	King Care Room, Faucet	F	9:25 AM	5	3	Y	Y	7/29/2021	Initial First Draw, Filtered.
King-21	Room KI-K1, Combination Sink, Glass Filler	C	8:38 AM	5	ND	N	Y	6/23/2022	Initial First Draw, Filtered.
King-27	Room 108, Combination Sink, Glass Filler	C	8:49 AM	5	ND	N	Y	6/23/2022	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE230030

King Elementary School									
Date of Sampling: January 4, 2023									
Sampler: Sabrina Fouche									
Sample #	Location	Type ¹	Time Collected	District Lead Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
King-32	Room 112, Combination Sink, Glass Filler	C	9:12 AM	5	ND	N	Y	6/23/2022	Initial First Draw, Filtered.
King-38	Room 115, Combination Sink, Glass Filler	C	9:16 AM	5	ND	N	Y	Unknown	Initial First Draw, Filtered.
King-45	Room 101, Combination Sink, Glass Filler	C	9:19 AM	5	ND	N	Y	6/23/2022	Initial First Draw, Filtered.
King-51	Room 104, Combination Sink, Glass Filler	C	8:46 AM	5	ND	N	Y	6/23/2022	Initial First Draw, Filtered.
King-57	Portable, Hydration Station, Bottle Fill	HS	9:33 AM	5	ND	Y	Y	Unknown	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L