



**Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE230030**

Lakewood Elementary School									
Date of Sampling: January 4, 2023									
Sampler: Victoria Heed									
Sample #	Location	Type ¹	Time Collected	District Lead Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Lakewood-01	Teacher's Lounge Across from Main Office, Add On Glass Filler	G	8:31 AM	5	ND ³	N	Y	7/13/2022	Initial First Draw, Filtered.
Lakewood-05	Room 109, Combination Sink, Glass Filler	C	8:35 AM	5	ND	N	Y	7/13/2022	Initial First Draw, Filtered.
Lakewood-16	Room A-4, Combination Sink, Glass Filler	C	8:56 AM	5	ND	N	Y	7/15/2022	Initial First Draw, Filtered.
Lakewood-20	Room A-2, Combination Sink, Glass Filler	C	9:01 AM	5	ND	N	Y	7/15/2022	Initial First Draw, Filtered.
Lakewood-26	Hallway, Outside of Kitchen, Hydration Station, Bottle Fill	HS	8:53 AM	5	ND	Y	Y	No Filter Light	Initial First Draw, Filtered.
Lakewood-36	Room D-4, Combination Sink, Glass Filler	C	8:44 AM	5	ND	N	Y	7/15/2022	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE230030

Lakewood Elementary School									
Date of Sampling: January 4, 2023									
Sampler: Victoria Heed									
Sample #	Location	Type ¹	Time Collected	District Lead Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Lakewood-40	Room D-6, Combination Sink, Glass Filler	C	8:42 AM	5	ND	N	Y	7/15/2022	Initial First Draw, Filtered.
Lakewood-44	Room D-2, Combination Sink, Glass Filler	C	8:49 AM	5	ND	N	Y	7/15/2022	Initial First Draw, Filtered.
Lakewood-52	Hallway, Outside of Gym, Hydration Station, Bottle Fill	HS	8:39 AM	5	ND	Y	Y	Green	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L