



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE230030

Lawton Elementary School									
Date of Sampling: January 5, 2023									
Sampler: Victoria Heed									
Sample #	Location	Type ¹	Time Collected	District Lead Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Lawton-13	Room 312, Combination Sink, Glass Filler	C	11:34 AM	5	ND ³	N	Y	6/16/2022	Initial First Draw, Filtered.
Lawton-16	Room 308, Combination Sink, Glass Filler	C	11:38 AM	5	ND	N	Y	6/16/2022	Initial First Draw, Filtered.
Lawton-20	Room 302, Combination Sink, Glass Filler	C	11:43 AM	5	ND	N	Y	6/16/2022	Initial First Draw, Filtered.
Lawton-24	Room 208, Combination Sink, Glass Filler	C	11:48 AM	5	ND	N	Y	6/15/2022	Initial First Draw, Filtered.
Lawton-25	Cafeteria, Hydration Station, Bottle Fill	HS	11:53 AM	5	ND	Y	Y	No Filter Light	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



**Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE230030**

Lawton Elementary School									
Date of Sampling: January 5, 2023									
Sampler: Victoria Heed									
Sample #	Location	Type ¹	Time Collected	District Lead Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Lawton-29	Room 204, Combination Sink, Glass Filler	C	11:57 AM	5	ND	N	Y	6/15/2022	Initial First Draw, Filtered.
Lawton-30	Room 202, Combination Sink, Glass Filler	C	12:01 PM	5	ND	N	Y	6/15/2022	Initial First Draw, Filtered.
Lawton-32	Room 101, Combination Sink, Glass Filler	C	12:05 PM	5	ND	N	Y	6/15/2022	Initial First Draw, Filtered.
Lawton-40	Room 109, Combination Sink, Glass Filler	C	11:26 AM	5	ND	N	Y	6/15/2022	Initial First Draw, Filtered.
Lawton-69	Hallway Outside Room 312, Hydration Station, Bottle Fill	HS	11:30 AM	5	ND	Y	Y	Green	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L