



Ann Arbor Public Schools  
 Drinking Water Analysis  
 Project Number: AE230030

Skyline High School									
Date of Sampling: January 3, 2023									
Sampler: Victoria Heed									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Skyline-02	Room C104, Choir Room, Left Porcelain Glass Filler	G	9:23 AM	5	ND <sup>3</sup>	N	Y	7/18/2022	Initial First Draw, Filtered.
Skyline-04	Room C110, Left Porcelain Glass Filler	G	9:30 AM	5	ND	N	Y	7/15/2022	Initial First Draw, Filtered.
Skyline-06	Room B424, Clinic, Combination Sink, Glass Filler	C	8:05 AM	5	ND	N	Y	9/12/2022	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools  
 Drinking Water Analysis  
 Project Number: AE230030

Skyline High School									
Date of Sampling: January 3, 2023									
Sampler: Victoria Heed									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Skyline-08	Room C116, Right Porcelain Glass Filler	G	9:35 AM	5	ND	N	Y	7/18/2022	Initial First Draw, Filtered.
Skyline-12	Room B331, Combination Sink, Glass Filler	C	8:15 AM	5	ND	N	Y	7/20/2022	Initial First Draw, Filtered.
Skyline-16	Girl's Pool Locker Room, Right Refrigerated Glass Filler	G	9:13 AM	5	ND	N	Y	Unknown Filter Date	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



**Ann Arbor Public Schools  
Drinking Water Analysis  
Project Number: AE230030**

Skyline High School									
Date of Sampling: January 3, 2023									
Sampler: Victoria Heed									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Skyline-19	Hallway, Floor 2, Between Serving Area and B211, Outside Men's Restroom, Left Refrigerated Glass Filler	G	8:24 AM	5	ND	N	Y	Unknown Filter Date	Initial First Draw, Filtered.
Skyline-21	Hallway, Floor 2, Between Serving Area and B211, Outside Woman's Restroom, Right Refrigerated Glass Filler	G	8:27 AM	5	ND	N	Y	Unknown Filter Date	Initial First Draw, Filtered.
Skyline-22	Room A119, Ice Machine	I	9:42 AM	5	ND	N	Y	Unknown Filter Date	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools  
 Drinking Water Analysis  
 Project Number: AE230030

Skyline High School									
Date of Sampling: January 3, 2023									
Sampler: Victoria Heed									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Skyline-23	Hallway, Floor 2, Outside Track, Left Refrigerated Glass Filler	G	8:41 AM	5	ND	N	Y	Unknown Filter Date	Initial First Draw, Filtered.
Skyline-26	Hallway, Floor 2, Outside Track, Right Refrigerated Glass Filler	G	8:42 AM	5	ND	N	Y	Unknown Filter Date	Initial First Draw, Filtered.
Skyline-32	Room A220, Photography Classroom, Combination Sink, Glass Filler	C	8:52 AM	5	ND	N	Y	7/18/2022	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools  
 Drinking Water Analysis  
 Project Number: AE230030

Skyline High School									
Date of Sampling: January 3, 2023									
Sampler: Victoria Heed									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Skyline-34	Floor 2, Room A225b, 3-Compartment Sink, Add on Glass Filler	G	8:46 AM	5	ND	N	Y	7/18/2022	Initial First Draw, Filtered.
Skyline-36	Room C216, Staff Lounge, Combination Sink, Glass Filler	C	8:32 AM	5	ND	N	Y	7/18/2022	Initial First Draw, Filtered.
Skyline-40	Weight Room, Hydration Station, Bottle Fill	HS	9:02 AM	5	ND	Y	Y	Green	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools  
 Drinking Water Analysis  
 Project Number: AE230030

Skyline High School									
Date of Sampling: January 3, 2023									
Sampler: Victoria Heed									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Skyline-49	Room B325, Combination Sink, Glass Filler	C	8:12 AM	5	ND	N	Y	7/20/2022	Initial First Draw, Filtered.
Skyline-39	Hallway, Floor 1, Outside Pool & Room C104, Hydration Station, Bottle Fill	HS	9:19 AM	5	ND	Y	Y	Green	Initial First Draw, Filtered.
Skyline-58	Room B425, Equality Center, Combination Sink, Glass Filler	C	10:00 AM	5	ND	N	Y	7/18/2022	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools  
 Drinking Water Analysis  
 Project Number: AE230030

Skyline High School									
Date of Sampling: January 3, 2023									
Sampler: Victoria Heed									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Skyline-64	Room C403-A, Combination Sink, Glass Filler	C	7:50 AM	5	ND	N	Y	7/18/2022	Initial First Draw, Filtered.
Skyline-20	Greenroom, Kitchen Faucet	KF	9:52 AM	5	3	Y	Y	9/4/2020	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L