



**Ann Arbor Public Schools  
Drinking Water Analysis  
Project Number: AE230030**

<b>Tappan Middle School</b>									
<b>Date of Sampling: January 4, 2023</b>									
<b>Sampler: Sabrina Fouche</b>									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Tappan-09	Hallway, Outside Room 288, Refridgerated, Glass Filler	G	1:52 PM	5	ND <sup>3</sup>	N	Y	Unknown	Initial First Draw, Filtered.
Tappan-12	Hallway, Outside Room 320, Hydration Station, Bottle Fill	HS	2:01 PM	5	ND	Y	Y	Green	Initial First Draw, Filtered.
Tappan-16	Kitchen, 2-Comp Sink, Add On Single Faucet, Right Faucet, Kitchen Faucet	KF	1:29 PM	5	ND	Y	Y	8/4/22	Initial First Draw, Filtered.
Tappan-20	Girl's Locker Room, Porcelain, Glass Filler	G	1:34 PM	5	ND	N	Y	8/4/22	Initial First Draw, Filtered.
Tappan-24	Room 192, Refridgerated, Glass Filler	G	1:38 PM	5	ND	N	Y	Unknown	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools  
 Drinking Water Analysis  
 Project Number: AE230030

Tappan Middle School									
Date of Sampling: January 4, 2023									
Sampler: Sabrina Fouche									
Sample #	Location	Type <sup>1</sup>	Time Collected	District Lead Action Level (ug/L) <sup>2</sup>	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date/Color	Notes
Tappan-28	Second Floor Teacher's Lounge, Combination Sink, Glass Filler	G	1:48 PM	5	ND	N	Y	8/25/21	Initial First Draw, Filtered.
Tappan-29	Room 256, Combination Sink, Glass Filler	G	1:44 PM	5	ND	N	Y	8/3/22	Initial First Draw, Filtered.
Tappan-31	Gymnasium, South Wall, Left Glass Filler, Bubbler Outlet	G	1:55 PM	5	2	N	Y	Unknown	Initial First Draw, Filtered.
Tappan-35	Hallway, Adjacent to Room 308, Across Stairwell, Hydration Station, Bottle Fill	HS	2:03 PM	5	ND	N	Y	Unknown	Initial First Draw, Filtered.
Tappan-50	Hallway, Outside Room 220, Hydration Station, Bottle Fill	HS	1:50 PM	5	ND	Y	Y	Green	Initial First Draw, Filtered.

1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, WC = Single Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, PB = Potable Bathroom Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee Machine, G = Glass Filler

2) [https://www.epa.gov/sites/default/files/2016-06/documents/npwdr\\_complete\\_table.pdf](https://www.epa.gov/sites/default/files/2016-06/documents/npwdr_complete_table.pdf)

3) ND = Non-Detected at Reported Detection Limit of 1 ug/L