



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE240030

Site: Bach Elementary School									
Sampling Type: Initial First Draw Sampling (IFD)									
Date of Sampling: February 17, 2024									
Sampler: Teagan Evans									
Sample #	Location	Fixture Type	Time Collected	District Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date	Notes
Bach-44	Hallway, Outside Room A-28, Hydration Station, Bottle Fill	Hydration Station	10:06 AM	5	ND	Y	N	N/A	
Bach-02	Room C-104, Combination Sink, Glass Filler	Combination Sink	10:40 AM	5	ND	N	N	N/A	
Bach-04	Room A-25, Combination Sink, Glass Filler	Combination Sink	10:16 AM	5	ND	N	N	N/A	
Bach-05	Room A-26, Combination Sink, Glass Filler	Combination Sink	10:12 AM	5	ND	N	N	N/A	
Bach-07	Room 19, Combination Sink, Glass Filler	Combination Sink	10:27 AM	5	ND	N	N	N/A	
Bach-10	Room 16, Combination Sink, Glass Filler	Combination Sink	10:23 AM	5	ND	N	N	N/A	
Bach-26	Room 22, Combination Sink, Glass Filler	Combination Sink	10:31 AM	5	ND	N	N	N/A	
Bach-35	Room A-28, Combination Sink, Glass Filler	Combination Sink	10:08 AM	5	ND	N	N	N/A	

*ND = Non-Detected at Reported Detection Limit of 1 ug/L