



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE240030

Site: Bryant Elementary School									
Sampling Type: Initial First Draw Sampling (IFD)									
Date of Sampling: February 16, 2024									
Sampler: Teagan Evans									
Sample #	Location	Fixture Type	Time Collected	District Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date	Notes
Bryant-01	Hallway, Outside Room 203, Refrigerated Glass Filler	Water Cooler	8:24 AM	5	ND	N	N	N/A	
Bryant-03	Kitchen, 3-Compartment Sink, Far Left, Add on Glass Filler	Glass Filler	8:33 AM	5	ND	N	N	N/A	
Bryant-05	Hallway, Between Gym and Boiler Room, Refrigerated Glass Filler	Water Cooler	8:39 AM	5	ND	N	N	N/A	
Bryant-08	Room 206, Combination Sink, Glass Filler	Combination Sink	8:46 AM	5	ND	N	N	N/A	
Bryant-09	Between Room 210 & 211, Combination Sink, Glass Filler	Combination Sink	8:52 AM	5	ND	N	N	N/A	
Bryant-11	Room 215, Combination Sink, Glass Filler	Combination Sink	9:00 AM	5	ND	N	N	N/A	
Bryant-19	Room 214, Combination Sink, Glass Filler	Combination Sink	9:06 AM	5	ND	N	N	N/A	
Bryant-23	Room 202, Combination Sink, Glass Filler	Combination Sink	9:12 AM	5	ND	N	N	N/A	

*ND = Non-Detected at Reported Detection Limit of 1 ug/L