



**Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE240030**

Site: Huron High School									
Sampling Type: Initial First Draw Sampling (IFD)									
Date of Sampling: January 27, 2024									
Sampler: Stephanie Waranauckas									
Sample #	Location	Fixture Type	Time Collected	District Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date	Notes
Huron-47	Hallway, Northwest Wing, Floor 2, Outside Upper Gym, Hydration Station, Bottle Fill	Hydration Station	2:17 PM	5	ND	Y	N	N/A	
Huron-17	Hallway, Northwest Wing, Floor 1, Between Fitness Center and Lower Gym, Left Refrigerated, Glass Filler	Water Cooler	4:07 PM	5	ND	N	N	N/A	
Huron-24	First Floor, Room 2101, Combination Sink, Glass Filler	Combination Sink	3:52 PM	5	2	N	N	N/A	
Huron-36	Southeast Wing, Floor 1, Hallway, Across from Room 7152, Refrigerated, Glass Filler	Water Cooler	3:31 PM	5	ND	N	N	N/A	
Huron-74	Cafeteria, East , Outside Service Area, Hydration Station, Bottle Fill	Hydration Station	4:13 PM	5	ND	Y	N	N/A	

*ND = Non-Detected at Reported Detection Limit of 1 ug/L

**Sampled from combination sink faucet. No sample taken from Glass Filler.

***Bottle Fill - No Flow. Sample taken from Bubbler Only.



**Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE240030**

Site: Huron High School									
Sampling Type: Initial First Draw Sampling (IFD)									
Date of Sampling: January 27, 2024									
Sampler: Stephanie Waranauckas									
Sample #	Location	Fixture Type	Time Collected	District Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date	Notes
Huron-39	Hallway, Northwest Wing, Floor 2, Across from Room 3201, Single Bottle Fill	Bottle Fill	2:30 PM	5	ND	N	N	N/A	
Huron-04	Hallway, Southeast Wing, Floor 1, Across from Main Office, Hydration Station, Bottle Fill	Hydration Station	4:35 PM	5	ND	Y	N	N/A	
Huron-11	Hallway, Northwest Wing, Floor 1, Across Room 1110, Refrigerated, Glass Filler	Water Cooler	4:05 PM	5	ND	N	N	N/A	
Huron-21	Northwest Wing, Pool, East, Near Diving Boards, Right Porcelain, Glass Filler	Single Bottle Fill	4:22 PM	5	ND	N	N	N/A	
Huron-53	Room 6218A/6218B, 2-Compartment Sink, Combination Sink, Glass Filler	Combination Sink	2:55 PM	5	ND	N	N	N/A	
Huron-57	Life Skills Room 6219, East Wall, Middle, 2-Compartment Sink, Combination Sink, Faucet	Combination Sink Faucet	3:05 PM	5	ND	Y	Y	7/6/2023	**

*ND = Non-Detected at Reported Detection Limit of 1 ug/L

**Sampled from combination sink faucet. No sample taken from Glass Filler.

***Bottle Fill - No Flow. Sample taken from Bubbler Only.



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE240030

Site: Huron High School									
Sampling Type: Initial First Draw Sampling (IFD)									
Date of Sampling: January 27, 2024									
Sampler: Stephanie Waranauckas									
Sample #	Location	Fixture Type	Time Collected	District Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date	Notes
Huron-63	Life Skills Room 6219, Ice Machine	Ice Machine	3:07 PM	5	ND	N	N	N/A	
Huron-69	Hallway, Floor 3, Outside Room 4300, Single Bottle Fill	Bottle Fill	2:45 PM	5	ND	N	N	N/A	
Huron-34	Hallway, Southeast Wing, Floor 1, Across from Room 7150, Hydration Station	Hydration Station	3:25 PM	5	ND	Y	N	N/A	Alternate Sample Location. ***
Huron-80	Hallway, Floor 3, Outside Room 4313, Hydration Station, Bottle Fill	Hydration Station	2:40 PM	5	ND	Y	N	N/A	

*ND = Non-Detected at Reported Detection Limit of 1 ug/L

**Sampled from combination sink faucet. No sample taken from Glass Filler.

***Bottle Fill - No Flow. Sample taken from Bubbler Only.