



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE240030

Site: King Elementary School									
Sampling Type: Initial First Draw Sampling (IFD)									
Date of Sampling: January 27, 2024									
Sampler: Stephanie Waranauckas									
Sample #	Location	Fixture Type	Time Collected	District Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date	Notes
King-08	Room 110, Commination Sink, Bottle Fill	Combination Sink	12:40 PM	5	ND	Y	Y	6/26/2023	
King-10	Clinic in Main Office, Combination Sink, Glass Filler	Combination Sink	12:50 PM	5	ND	Y	Y	6/26/2023	
King-16	Hallway Across from Main Office, Hydration Station, Bottle Fill	Hydration Station	12:55 PM	5	ND	Y	N	N/A	
King-18	Hallway, Between Music Room and Gym, Hydration Station, Bottle Fill	Hydration Station	1:05 PM	5	ND	Y	N	N/A	
King-34	Room 113, Combination Sink, Glass Filler	Combination Sink	1:10 PM	5	ND	N	N/A	N/A	
King-40	Room 116, Combination Sink, Glass Filler	Combination Sink	1:17 PM	5	ND	N	Y	6/23/2023	
King-44	Room 118, Combination Sink, Glass Filler	Combination Sink	1:22 PM	5	ND	N	Y	6/23/2023	
King-47	Room 102, Combination Sink, Glass Filler	Combination Sink	1:30 PM	5	ND	N	Y	6/26/2023	
King-52	Room 105, Combination Sink, Glass Filler	Combination Sink	1:35 PM	5	ND	N	Y	6/26/2023	
King-61	Hallway, Outside Room C-101, Hydration Station, Bottle Fill	Hydration Station	1:40 PM	5	ND	Y	N/A	N/A	

*ND = Non-Detected at Reported Detection Limit of 1 ug/L