



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE240030

| Site: Mitchell Elementary School | | | | | | | | | |
|--|--|-------------------|----------------|-----------------------------------|---------------------|---------------------|------------------------|-------------|-------|
| Sampling Type: Initial First Draw Sampling (IFD) | | | | | | | | | |
| Date of Sampling: February 16, 2024 | | | | | | | | | |
| Sampler: Teagan Evans | | | | | | | | | |
| Sample # | Location | Fixture Type | Time Collected | District Lead Action Level (ug/L) | Lead Results (ug/L) | Aerator Present Y/N | POU Filter Present Y/N | Filter Date | Notes |
| Mitchell-14 | Hallway, Outside Multi-Purpose Room, Left of Girl's Bathroom, Hydration Station, Bottle Fill | Hydration Station | 12:52 PM | 5 | ND | Y | N | N/A | |
| Mitchell-44 | Room 14, Combination Sink, Glass Filler | Combination Sink | 12:37 PM | 5 | ND | N | N | N/A | |
| Mitchell-49 | Room 16, Combination Sink, Glass Filler | Combination Sink | 12:42 PM | 5 | ND | N | N | N/A | |
| Mitchell-59 | Hallway Outside Room 6, Refrigerated, Glass Filler | Water Cooler | 12:58 PM | 5 | ND | N | N | N/A | |
| Mitchell-66 | Room 22, Combination Sink, Glass Filler | Combination Sink | 1:04 PM | 5 | ND | N | N | N/A | |
| Mitchell-68 | Room 23, Combination Sink, Glass Filler | Combination Sink | 1:08 PM | 5 | ND | N | N | N/A | |

*ND = Non-Detected at Reported Detection Limit of 1 ug/L