



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE240030

Site: Pathways to Success Academic Campus									
Sampling Type: Initial First Draw Sampling (IFD)									
Date of Sampling: February 16, 2024									
Sampler: Dean Johnson									
Sample #	Location	Fixture Type	Time Collected	District Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date	Notes
Pathways-05	Hallway, Outside Room 208, Hydration Station, Bottle Fill	Hydration Station	3:10 PM	5	ND	Y	N/A	N/A	
Pathways-08	Hallway, Outside Room 308, Hydration Station, Bottle Fill	Hydration Station	3:29 PM	5	ND	Y	N/A	N/A	
Pathways-10	Media Center, Staff Workroom, Combination Sink, Glass Filler	Combination Sink	3:22 PM	5	ND	Y	Y	7/17/2023	
Pathways-19	Hallway, Outside Gym, Hydration Station, Bottle Fill	Hydration Station	3:26 PM	5	ND	Y	N/A	N/A	

*ND = Non-Detected at Reported Detection Limit of 1 ug/L