



**Ann Arbor Public Schools**  
**Drinking Water Analysis**  
**Project Number: AE240030**

| Site: Pioneer High School         |   |              |                |                                   |                     |                     |                        |             |  |
|-----------------------------------|---|--------------|----------------|-----------------------------------|---------------------|---------------------|------------------------|-------------|--|
| Initial First Draw Sampling (IFD) |   |              |                |                                   |                     |                     |                        |             |  |
| Date of Sampling: June 19, 2024   |   |              |                |                                   |                     |                     |                        |             |  |
| Sampler: Teagan Evans             |   |              |                |                                   |                     |                     |                        |             |  |
| Sample #                          | Location  | Fixture Type | Time Collected | District Lead Action Level (ug/L) | Lead Results (ug/L) | Aerator Present Y/N | POU Filter Present Y/N | Filter Date | Notes  |
| Pioneer-18                        | Pool Deck, Adjacent to Timer Clock, Bubbler             | Bubbler      | N/A            | 5                                 | N/A                 | Y                   | N                      | N/A         | Not sampled. Boys and girls swim teams were practicing in the pool area and the fixture was used. Alternate sample taken at Pioneer-17.      |
| Pioneer-17                        | Pool Deck, Adjacent to Timer Clock, Bubbler             | Bubbler      | 8:56 AM        | 5                                 | ND                  | Y                   | N                      | N/A         | Alternate sample for Pioneer-18.   |
| Pioneer-19                        | Auxiliary Gym, Outside Boy's Locker Room, Bubbler       | Bubbler      | N/A            | 5                                 | N/A                 | Y                   | N                      | N/A         | Not sampled. Girls basketball team was practicing in the gym area and the fixture was previously used. Alternate sample taken at Pioneer-20. |
| Pioneer-20                        | Auxiliary Gym, Outside Girl's Locker Room, Glass Filler | Glass Filler | 9:11 AM        | 5                                 | ND                  | Y                   | N                      | N/A         | Alternate sample for Pioneer-19.   |

\*ND = Non-Detected at Reported Detection Limit of 1 ug/L



**Ann Arbor Public Schools**  
**Drinking Water Analysis**  
**Project Number: AE240030**

| Site: Pioneer High School         |  |                   |                |                                   |                     |                     |                        |             |                          |
|-----------------------------------|--|-------------------|----------------|-----------------------------------|---------------------|---------------------|------------------------|-------------|--------------------------|
| Initial First Draw Sampling (IFD) |  |                   |                |                                   |                     |                     |                        |             |                          |
| Date of Sampling: June 19, 2024   |  |                   |                |                                   |                     |                     |                        |             |                          |
| Sampler: Teagan Evans             |  |                   |                |                                   |                     |                     |                        |             |                          |
| Sample #                          | Location   | Fixture Type      | Time Collected | District Lead Action Level (ug/L) | Lead Results (ug/L) | Aerator Present Y/N | POU Filter Present Y/N | Filter Date | Notes                    |
| Pioneer-22                        | Girl's Auxiliary Gym Locker Room, West Wall, Bubblers                              | Bubbler           | 10:50 AM       | 5                                 | ND                  | Y                   | N                      | N/A         |                          |
| Pioneer-75                        | Main Outbuilding, Room 103, West Concessions, Three Compartment Sink, Right Faucet | Kitchen Faucet    | 10:25 AM       | 5                                 | ND                  | Y                   | N                      | N/A         |                          |
| Pioneer-14                        | Hallway, Outside Room C-304, Hydration Station, Bottle Fill                        | Hydration Station | 12:12 PM       | 5                                 | ND                  | Y                   | Y                      | N/A         | Filter status is Yellow. |
| Pioneer-15                        | Main Gym, Near North Entrance, Bubblers  | Bubbler           | 9:26 AM        | 5                                 | ND                  | Y                   | N                      | N/A         |                          |

\*ND = Non-Detected at Reported Detection Limit of 1 ug/L



**Ann Arbor Public Schools**  
**Drinking Water Analysis**  
**Project Number: AE240030**

| Site: Pioneer High School         |   |              |                |                                   |                     |                     |                        |             |  |
|-----------------------------------|---|--------------|----------------|-----------------------------------|---------------------|---------------------|------------------------|-------------|--|
| Initial First Draw Sampling (IFD) |   |              |                |                                   |                     |                     |                        |             |  |
| Date of Sampling: June 19, 2024   |   |              |                |                                   |                     |                     |                        |             |  |
| Sampler: Teagan Evans             |   |              |                |                                   |                     |                     |                        |             |  |
| Sample #                          | Location  | Fixture Type | Time Collected | District Lead Action Level (ug/L) | Lead Results (ug/L) | Aerator Present Y/N | POU Filter Present Y/N | Filter Date | Notes  |
| Pioneer-23                        | Girl's Auxiliary Gym Locker Room, East Wall, Bubblers     | Bubbler      | 9:05 AM        | 5                                 | ND                  | Y                   | N                      | N/A         |  |
| Pioneer-84                        | Outbuilding, North of Tennis Courts, Bubblers, Glass Fill | Bubbler      | N/A            | 5                                 | N/A                 | Y                   | N                      | N/A         | Not sampled. Unable to verify if fixture was used. The courts were in use early this morning and afternoon. No alternate sample taken. |
| Pioneer-24                        | Room A-131, Ice Machine                                   | Ice Machine  | 11:05 AM       | 5                                 | ND                  | Y                   | Y                      | N/A         |  |
| Pioneer-26                        | Room A-131, Water Cooler, Glass Filler                    | Water Cooler | 11:08 AM       | 5                                 | ND                  | Y                   | N                      | N/A         |  |

\*ND = Non-Detected at Reported Detection Limit of 1 ug/L



**Ann Arbor Public Schools**  
**Drinking Water Analysis**  
**Project Number: AE240030**

| Site: Pioneer High School         |   |                   |                |                                   |                     |                     |                        |             |   |
|-----------------------------------|---|-------------------|----------------|-----------------------------------|---------------------|---------------------|------------------------|-------------|---|
| Initial First Draw Sampling (IFD) |   |                   |                |                                   |                     |                     |                        |             |   |
| Date of Sampling: June 19, 2024   |   |                   |                |                                   |                     |                     |                        |             |   |
| Sampler: Teagan Evans             |   |                   |                |                                   |                     |                     |                        |             |   |
| Sample #                          | Location  | Fixture Type      | Time Collected | District Lead Action Level (ug/L) | Lead Results (ug/L) | Aerator Present Y/N | POU Filter Present Y/N | Filter Date | Notes   |
| Pioneer-37                        | Kitchen, Right Plumbed Coffee Machine                       | Coffee Machine    | N/A            | 5                                 | N/A                 | N/A                 | N/A                    | N/A         | Not sampled. Pioneer-37 not currently in use on summer break. Employee confirmed the fixture is not in use currently. Alternate sample taken at Pioneer-40. |
| Pioneer-40                        | Kitchen, Between Ovens and Stove Hood 2, Kitchen Sink       | Kitchen Sink      | 1:44 PM        | 5                                 | ND                  | Y                   | N                      | N/A         | Alternate sample for Pioneer-37.  |
| Pioneer-44                        | Room E101, Art Room, South Wall, Single Add on Glass Filler | Glass Filler      | 11:51 AM       | 5                                 | ND                  | Y                   | N                      | N/A         | POU date states 7-26-22.  |
| Pioneer-48                        | Hallway, Outside Room C-126, Hydration Station, Bottle Fill | Hydration Station | 12:00 PM       | 5                                 | ND                  | Y                   | Y                      | N/A         |   |

\*ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools  
 Drinking Water Analysis  
 Project Number: AE240030

| Site: Pioneer High School         |   |                   |                |                                   |                     |                     |                        |             |                          |
|-----------------------------------|---|-------------------|----------------|-----------------------------------|---------------------|---------------------|------------------------|-------------|--------------------------|
| Initial First Draw Sampling (IFD) |   |                   |                |                                   |                     |                     |                        |             |                          |
| Date of Sampling: June 19, 2024   |   |                   |                |                                   |                     |                     |                        |             |                          |
| Sampler: Teagan Evans             |   |                   |                |                                   |                     |                     |                        |             |                          |
| Sample #                          | Location  | Fixture Type      | Time Collected | District Lead Action Level (ug/L) | Lead Results (ug/L) | Aerator Present Y/N | POU Filter Present Y/N | Filter Date | Notes                    |
| Pioneer-50                        | Teacher's Lounge, Combination Sink, Glass Filler                | Combination Sink  | 12:48 PM       | 5                                 | ND                  | Y                   | Y                      | N/A         |                          |
| Pioneer-51                        | Room E-110, Combination Sink, Glass Filler                      | Combination Sink  | 11:35 AM       | 5                                 | ND                  | Y                   | Y                      | N/A         |                          |
| Pioneer-65                        | Hallway, Outside Room D-203/205, Hydration Station, Bottle Fill | Hydration Station | 12:26 PM       | 5                                 | ND                  | Y                   | Y                      | N/A         | Filter status is Yellow. |
| Pioneer-66                        | Room D-214, Combination Sink, Glass Filler                      | Combination Sink  | 12:30 PM       | 5                                 | 1                   | Y                   | Y                      | N/A         |                          |

\*ND = Non-Detected at Reported Detection Limit of 1 ug/L



**Ann Arbor Public Schools**  
**Drinking Water Analysis**  
**Project Number: AE240030**

| Site: Pioneer High School         |   |                  |                |                                   |                     |                     |                        |             |                            |
|-----------------------------------|---|------------------|----------------|-----------------------------------|---------------------|---------------------|------------------------|-------------|----------------------------|
| Initial First Draw Sampling (IFD) |   |                  |                |                                   |                     |                     |                        |             |                            |
| Date of Sampling: June 19, 2024   |   |                  |                |                                   |                     |                     |                        |             |                            |
| Sampler: Teagan Evans             |   |                  |                |                                   |                     |                     |                        |             |                            |
| Sample #                          | Location  | Fixture Type     | Time Collected | District Lead Action Level (ug/L) | Lead Results (ug/L) | Aerator Present Y/N | POU Filter Present Y/N | Filter Date | Notes                      |
| Pioneer-77                        | Main Outbuilding, Room 123 East Concessions, Three Compartment Sink, Right Faucet | Kitchen Faucet   | 10:17 AM       | 5                                 | ND                  | Y                   | Y                      | N/A         | No POU filter date listed. |
| Pioneer-78                        | Main Outbuilding, Room 117 Officials, Ice Machine                                 | Ice Machine      | 10:09 AM       | 5                                 | ND                  | Y                   | Y                      | N/A         |                            |
| Pioneer-82                        | Main Outbuilding, Room 117 Officials, Combination Sink, Glass Filler              | Combination Sink | 10:02 AM       | 5                                 | ND                  | Y                   | Y                      | N/A         | No POU filter date listed. |
| Pioneer-25                        | Room A-131, Single Sink, Faucet   | Faucet           | 11:10 AM       | 5                                 | 2                   | Y                   | Y                      | N/A         | POU date states 1-5-23.    |

\*ND = Non-Detected at Reported Detection Limit of 1 ug/L



Ann Arbor Public Schools  
Drinking Water Analysis  
Project Number: AE240030

| Site: Pioneer High School         |   |              |                |                                   |                     |                     |                        |             |                          |
|-----------------------------------|---|--------------|----------------|-----------------------------------|---------------------|---------------------|------------------------|-------------|--------------------------|
| Initial First Draw Sampling (IFD) |   |              |                |                                   |                     |                     |                        |             |                          |
| Date of Sampling: June 19, 2024   |   |              |                |                                   |                     |                     |                        |             |                          |
| Sampler: Teagan Evans             |   |              |                |                                   |                     |                     |                        |             |                          |
| Sample #                          | Location  | Fixture Type | Time Collected | District Lead Action Level (ug/L) | Lead Results (ug/L) | Aerator Present Y/N | POU Filter Present Y/N | Filter Date | Notes                    |
| Pioneer-04                        | Main Office Suite, Infirmary S-174, Clinic, Ice Machine | Ice Machine  | 1:27 PM        | 5                                 | ND                  | Y                   | Y                      | N/A         | POU date states 9-25-23. |

\*ND = Non-Detected at Reported Detection Limit of 1 ug/L