



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE240030

Site: Pittsfield Elementary School									
Sampling Type: Initial First Draw Sampling (IFD)									
Date of Sampling: February 16, 2024									
Sampler: Stephanie Waranauckas									
Sample #	Location	Fixture Type	Time Collected	District Lead Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	POU Filter Present Y/N	Filter Date	Notes
Pittsfield-33	Room 111, Combination Sink, Glass Filler	Combination Sink	12:55 PM	5	ND	Y	Y	6/27/2023	
Pittsfield-09	Room 106, Combination Sink, Glass Filler	Combination Sink	12:40 PM	5	ND	Y	Y	6/27/2023	
Pittsfield-12	Room 109, Combination Sink, Glass Filler	Combination Sink	12:45 PM	5	ND	Y	Y	6/27/2023	
Pittsfield-23	Room 104, Combination Sink, Glass Filler	Combination Sink	12:30 PM	5	ND	Y	Y	6/27/2023	
Pittsfield-29	Room 114, Combination Sink, Glass Filler	Combination Sink	1:05 PM	5	ND	Y	Y	6/27/2023	
Pittsfield-35	Music Room, Combination Sink, Glass Filler	Combination Sink	12:50 PM	5	ND	Y	Y	6/27/2023	
Pittsfield-39	Media Center, Combination Sink, Glass Filler	Combination Sink	1:20 PM	5	ND	Y	Y	6/22/2022	

*ND = Non-Detected at Reported Detection Limit of 1 ug/L