



**Ann Arbor Public Schools
Legionella Sampling Analysis
Project Number: AE200779**

Community High School										
Date of Sampling: 11-11-2020										
Sampler: Brendan Koziol										
Sample #	Location	Time Collected	Bottle Type	Chlorine (ppm)	Temp °C	pH	Legionella Pneumophila Lab Result	Other Legionella Species ³ Lab Results	Total Legionella raw ct.	Total Legionella (cfu (colony forming units)/ml)
Community-01	Main Office, Second Floor, In Closet, Staff Single Sink	1:25 PM	Bioswab	0.01	22.1	7.73	ND	ND	ND	<20
Community-01	Main Office, Second Floor, In Closet, Staff Single Sink	1:27 PM	1 Liter	0.01	22.1	7.73	ND	ND	ND	<0.1
Community-13	Media Center, Single Sink	1:50 PM	Bioswab	0.01	21.5	7.71	ND	ND	ND	<20
Community-13	Media Center, Single Sink	1:53 PM	1 Liter	0.01	21.5	7.71	ND	ND	ND	<0.1
Community-NP-01	Kitchen, Left Non-potable Faucet	1:10 PM	Bioswab	0.00	23.1	10.16	ND	ND	ND	<20
Community-NP-01	Kitchen, Left Non-potable Faucet	1:12 PM	1 Liter	0.00	23.1	10.16	ND	ND	ND	<0.1
Community-NP-02	Room 317, Non-potable Faucet	2:07 PM	Bioswab	0.05	22.5	9.12	ND	ND	ND	<20
Community-NP-02	Room 317, Non-potable Faucet	2:10 PM	1 Liter	0.05	22.5	9.12	ND	ND	ND	<0.1

- 1) <0.1 is the detection limit for Legionella in bulk water samples
- 2) <20 is the detection limit for Legionella in bioswab samples
- 3) See attached analytical results for full list of other Legionella species

Community High School Sampling Results Table

Community High School				
Location	Parameter	Result	MCL/AL	Method Reference
Community-01: Main Office, Second Floor, in Closet, Staff Single Sink	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
Community-04: Hallway, Outside Room 310, Hydration Station, Bottle Fill	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
Community-15: Hallway, Outside Room 212, Hydration Station, Bottle Fill	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
Community-17: Hallway, Across from Room 111, Hydration Station, Bottle Fill	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
Community-18: Hallway, Outside Room 315, Hydration Station, Bottle Fill	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035
	Total Residual Chlorine	0.0 PPM	N/A	N/A
Community-20: Kitchen, Single Prep Sink	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Total Coliforms	Negative	Zero	ATP D05-0035