

## AAPS Testing for Lead in Drinking Water Program Results

<u>Parts Per Billion</u>	<u># of Samples</u>	<u>% of Samples</u>
Bottled Water Standard - 5 ppb	433	95% Below AAPS Action Level (5 or less parts per billion)
EPA Standard - 15 ppb	18	4% Below EPA Action Level but Above AAPS Action Level (6-15 parts per billion)
Above EPA Standard - > 15 ppb	5	1% Above AAPS and EPA Action Level (greater than 15 parts per billion)
<hr/>		
<b>TOTAL Drinking Water Sources Tested</b>	<b>456</b>	<b>100%</b>