



www.archenvgroup.com
healthAIR - Industrial Hygiene Services
cleanWATER - Consulting & Testing Services
safeEARTH - Hazardous Waste & Recycling Services

February 21, 2022

Mr. Bernie Rice
Executive Director, Physical Properties
Ann Arbor Public Schools
2555 South State Street
Ann Arbor, Michigan 48104

RE: **Project #AE210780**
Asbestos Abatement Report
Community High School

Dear Mr. Rice:

Per your request, Arch Environmental Group, Inc. (AEG) conducted project coordination and air monitoring activities for a small-scale, short duration asbestos abatement project at Community High School on February 18-19, 2022. Environmental Maintenance Engineers, a State of Michigan licensed asbestos abatement contractor, removed and disposed of asbestos plaster in the First Floor West Hall and Stairwell. The asbestos ceiling plaster was removed using Class II procedures and wet methods inside of a full negative enclosure. The asbestos plaster was properly disposed of as asbestos waste.

AEG conducted air monitoring during abatement activities during the abatement activities. The collected air samples have been analyzed utilizing Phase Contrast Microscopy (PCM) in accordance with NIOSH 7400 Methodologies. AEG uses the following nomenclature for referencing different types of air samples:

FB	Field Blank
SS	Set-Up Sample
PS	Personal Sample
PA	Clearance (Post-Abatement) Sample

Following a thorough visual inspection of the project area, the PCM clearance samples collected in the First Floor West Hall and Stairwell at Community High School on February 18-19, 2022, were analyzed below the AHERA PCM Clearance Level of 0.01 fibers per cubic centimeter (f/cc). The project areas shall be considered safe for re-occupancy.

Arch Environmental Group, Inc. looks forward to working with you in the future and helping you to address any concerns regarding environmental health and safety. If you have any questions regarding this report, or if I can be of further assistance please feel free to contact me at (248) 426-0165.

Project #AE210780

Asbestos Abatement Project Report

Ann Arbor Public Schools

Community High School

Page 2

Sincerely,

Arch Environmental Group, Inc.
Environmental Services



Tinh Nguyen
Field Technician, healthAIR

Attachments: Asbestos Daily Project Reports
Contractor Documentation

File: AE210780

Attachment
Asbestos Daily Project Reports



ASBESTOS DAILY PROJECT REPORTS

Contractor and Materials Information

Client:	Ann Arbor Public Schools	Date:	2/18/2022	Consultant:	Arch Environmental Group, Inc.
Building:	Community High School	Project Technician:	Eric Mayo	Abatement Contractor:	Environmental Maintenance Engineers, Inc.
Location:	First Floor West Hallway, First Floor Southeast Stairwell, Second Floor Main Hallway (West			Competent Person:	Shane Niblock
Project #:	AE210780				

Abatement Personnel Information

Workers / Accreditation Numbers

Name: Shane Niblock Type: Supervisor
 Accred #: A43597 Training: 10/24/2021
 Exp. Date: 12/18/2022 Fit test: 7/15/2021
 Activity: Removal of ceilings PWO: 6/24/2021
 Personal #: PS1

Name: Christopher Treglown Type: Worker
 Accred #: A36314 Training: 10/30/2021
 Exp. Date: 1/29/2023 Fit test: 7/15/2021
 Activity: Set-up Only PWO: 1/12/2022
 Personal #: PS1

Name: Bradley Altherr Type: Supervisor
 Accred #: A45730 Training: 5/15/2021
 Exp. Date: 6/4/2022 Fit test: 7/15/2021
 Activity: Set-up Only PWO: 5/14/2021
 Personal #: PS1

Abatement Personnel Information

Workers / Accreditation Numbers

Name: Type:
 Accred #: Training:
 Exp. Date: Fit test:
 Activity: PWO:
 Personal #:

Name: Type:
 Accred #: Training:
 Exp. Date: Fit test:
 Activity: PWO:
 Personal #:

Name: Type:
 Accred #: Training:
 Exp. Date: Fit test:
 Activity: PWO:
 Personal #:

Materials Abated - Quantity & Location

Material	sf/lf/#	Locations
Other Class II	inging hangar	First Floor West Hallway

Additional Work Activities

Were work activities conducted that were not included in original scope-of-work or that need to be tracked on a T&M basis?
No



ASBESTOS DAILY PROJECT REPORTS

Air Sample Analysis Information

Client:	Ann Arbor Public Schools	Samples Collected By:	Eric Mayo
Building:	Community High School	Sample Collection Date:	2/18/2022
Location:	First Floor West Hallway, First Floor Southeast Stairwell, Second Floor Main Hallway	Samples Analyzed By:	Eric Mayo
Project #:	AE210780	Sample Analysis Date:	2/18/2022

Sample ID	Sample Location	Start/End	Total Time (min)	Flow Rate (Lpm)	Volume (L)	Concentration (f/cc)	Density (f/mm ²)
FB1	Sample prepared on-site.	--	--	--	--	--	2.55
FB2	Sample prepared on-site.	--	--	--	--	--	3.18
SS1	Second Floor West Hallway	6:00 PM	120	7.968	956	0.003	8.28
		8:00 PM					
SS2	First Floor West Hallway	6:00 PM	120	8.750	1050	0.003	12.10
		8:00 PM					
SS3	Second Floor West Hallway	8:00 PM	60	7.968	478	0.006	7.64
		9:00 PM					

AHERA PCM Clearance Level = 0.010 f/cc

AHERA TEM Clearance Level = 70 AS/mm²

State of Michigan PCM Clearance Level = 0.050 f/cc

Project Area Clearance Information

N/A



ASBESTOS DAILY PROJECT REPORTS

OSHA Personal Air Sample Analysis

Client:	Ann Arbor Public Schools	Samples Collected By:	Eric Mayo
Building:	Community High School	Sample Collection Date:	2/18/2022
Location:	First Floor West Hallway, First Floor Southeast Stairwell, Second Floor Main Hallway	Samples Analyzed By:	Eric Mayo
Project #:	AE210780	Sample Analysis Date:	2/18/2022

Sample ID	Sample Location	Start/End	Total Time (min)	Flow Rate (Lpm)	Volume (L)	Concentration (f/cc)	Density (f/mm ²)
PS1 Series	Shane Niblock	7:45 PM	150	2.0	300	0.018	*
		10:15 PM				0.006	
Activity:	hanging ceiling anchors						
PS1	Shane Niblock	7:45 PM	30	2.0	60	0.045	6.37
		8:15 PM					
PS1R1	Shane Niblock	8:15 PM	120	2.0	240	0.011	7.64
		10:15 PM					

OSHA Permissible Exposure Limit = 0.100 f/cc, 8 hr TWA

OSHA STEL Limit = 1.0 f/cc

* = 8 hr Time Weighted Average



ASBESTOS DAILY PROJECT REPORTS

Contractor and Materials Information

Client:	Ann Arbor Public Schools	Date:	2.19.2022	Consultant:	Arch Environmental Group, Inc.
Building:	Community High School	Project Technician:	Thinh Nguyen	Abatement Contractor:	Environmental Maintenance Engineers, Inc.
Location:	First floor hallway and stairway	Competent Person:	Shane Niblock		
Project #:	AE210780				

Abatement Personnel Information

Workers / Accreditation Numbers

Name: Shane Niblock Type: Supervisor
Accred #: A43597 Training: 10/24/2021
Exp. Date: 12/18/2022 Fit test: 7/15/2021
Activity: Supervisor PWO: 6/24/2021
Personal #: N/A (No abate. activities)

Name: Bradley Altherr Type: Supervisor
Accred #: A45730 Training: 5/15/2021
Exp. Date: 6/4/2022 Fit test: 7/15/2021
Activity: Removal of misc. NF PWO: 5/14/2021
Personal #: PS1

Name: Erik Richardson Type: Supervisor
Accred #: A52387 Training: 5/15/2021
Exp. Date: 6/5/2022 Fit test: 7/15/2021
Activity: Removal of misc. NF PWO: 12/3/2021
Personal #: PS1

Name: Matthew Kelly Type: Supervisor
Accred #: A34636 Training: 5/15/2021
Exp. Date: 7/28/2022 Fit test: 7/15/2021
Activity: Removal of misc. NF PWO: 10/11/2021
Personal #: PS1

Abatement Personnel Information

Workers / Accreditation Numbers

Name: Nathaniel Hil Type: Supervisor
Accred #: A30676 Training: 11/28/2021
Exp. Date: 3/11/2022 Fit test: 7/15/2021
Activity: Removal of misc. NF PWO: 8/19/2021
Personal #: PS1

Name: Type:
Accred #: Training:
Exp. Date: Fit test:
Activity: PWO:
Personal #:

Name: Type:
Accred #: Training:
Exp. Date: Fit test:
Activity: PWO:
Personal #:

Name: Type:
Accred #: Training:
Exp. Date: Fit test:
Activity: PWO:
Personal #:

Materials Abated - Quantity & Location

Material	sf/lf/#	Locations
Other Class II	5	First floor hallway and stairway

Additional Work Activities

Were work activities conducted that were not included in original scope-of-work or that need to be tracked on a T&M basis?

No



ASBESTOS DAILY PROJECT REPORTS

Air Sample Analysis Information

Client:	Ann Arbor Public Schools	Samples Collected By:	Thinh Nguyen
Building:	Community High School	Sample Collection Date:	2.19.2022
Location:	First floor hallway and stairway	Samples Analyzed By:	Thinh Nguyen
Project #:	AE210780	Sample Analysis Date:	2.19.2022

Sample ID	Sample Location	Start/End	Total Time (min)	Flow Rate (Lpm)	Volume (L)	Concentration (f/cc)	Density (f/mm ²)
FB1	Sample prepared on-site.	--	--	--	--	--	0.00
FB2	Sample prepared on-site.	--	--	--	--	--	0.00
PA1	North west stairway	9:15 AM	135	14.56	1966	0.001	0.00
		11:30 AM					
PA2	South 1st floor hallway	10:15 AM	135	14.4	1944	0.001	0.00
		12:30 PM					
PA3	Outside main office on 2nd floor hallway	11:15 AM	135	14.2	1917	0.001	0.00
		1:30 PM					

AHERA PCM Clearance Level = 0.010 f/cc

AHERA TEM Clearance Level = 70 AS/mm²

State of Michigan PCM Clearance Level = 0.050 f/cc

Project Area Clearance Information

Passed



ASBESTOS DAILY PROJECT REPORTS

OSHA Personal Air Sample Analysis

Client:	Ann Arbor Public Schools	Samples Collected By:	Thinh Nguyen
Building:	Community High School	Sample Collection Date:	2.19.2022
Location:	First floor hallway and stairway	Samples Analyzed By:	Thinh Nguyen
Project #:	AE210780	Sample Analysis Date:	2.19.2022

Sample ID	Sample Location	Start/End	Total Time (min)	Flow Rate (Lpm)	Volume (L)	Concentration (f/cc)	Density (f/mm ²)
PS1 Series	Erik Richardson	8:45 AM	180	2.0	360	0.015	*
		11:45 AM				0.006	
Activity:	Removal of plaster, installation of unistruts, adjustment of light hangers						
PS1	Erik Richardson	8:45 AM	30	2.0	60	0.045	0.00
		9:15 AM					
PS1R1	Erik Richardson	9:15 AM	150	2.0	300	0.009	0.00
		11:45 AM					

OSHA Permissible Exposure Limit = 0.100 f/cc, 8 hr TWA

OSHA STEL Limit = 1.0 f/cc

* = 8 hr Time Weighted Average

Attachment
Contractor Documentation

Contractor Number
C2684

Expiration Date
12/8/2022

State of Michigan
Department of Labor and Economic Opportunity
Environmental Maintenance Engineers, Inc.

has satisfactorily met the requirements of Michigan Public Act 135 of 1986,
as amended, and is hereby recognized as a

LICENSED ASBESTOS ABATEMENT CONTRACTOR

Type II (5 + employees)

The issuance of this license does not ensure that asbestos indemnification insurance coverage has been acquired by the licensee. This license is nontransferable.

MIO 3003 (03/2019)
Authority: Michigan Public Act 135 of 1986, as amended

155663

Environmental Maintenance Engineers, Inc.
25851 Trowbridge Street
Inkster, MI 48141

The Michigan Department of Labor and Economic Opportunity (LEO) has reviewed and approved your application for a Michigan Asbestos Abatement Contractors License. The License Certificate is valid for a period of one year.

The Department is requiring each licensed asbestos abatement contractor to notify the Department of any asbestos abatement project exceeding 10 linear feet or 15 square feet of friable asbestos containing material. This notification must reach the office of the Asbestos Program at least 10 days before the beginning of each project. If for any reason there are revisions or modifications to a notification, your company must notify LEO by FAX (517.284.7700), telephone, or email (asbestos@michigan.gov). If the revision is via telephone, your company must follow-up with a formal written revision.

Please be advised, your company must continue to maintain records of post-abatement air monitoring results. LEO can and may request these post asbestos abatement monitoring results periodically. Please be reminded that any additional or new employees must be accredited before they engage in any asbestos abatement activities.

To apply for renewal of this license, please submit an application no sooner than 90 days and no later than 30 days before the license expires. The Department must also be notified of any address or ownership changes. Project notifications and questions regarding your license should be directed to the Michigan Department of Labor and Economic Opportunity, MIOSHA Asbestos Program, P.O. Box 30671, Lansing, Michigan 48909, 517.284.7698.

Dan W. Maki

Dan W. Maki
Safety and Health Manager



CERTIFICATE OF LIABILITY INSURANCE

DATE (MM/DD/YYYY)
1/27/2022

THIS CERTIFICATE IS ISSUED AS A MATTER OF INFORMATION ONLY AND CONFERS NO RIGHTS UPON THE CERTIFICATE HOLDER. THIS CERTIFICATE DOES NOT AFFIRMATIVELY OR NEGATIVELY AMEND, EXTEND OR ALTER THE COVERAGE AFFORDED BY THE POLICIES BELOW. THIS CERTIFICATE OF INSURANCE DOES NOT CONSTITUTE A CONTRACT BETWEEN THE ISSUING INSURER(S), AUTHORIZED REPRESENTATIVE OR PRODUCER, AND THE CERTIFICATE HOLDER.

IMPORTANT: If the certificate holder is an ADDITIONAL INSURED, the policy(ies) must be endorsed. If SUBROGATION IS WAIVED, subject to the terms and conditions of the policy, certain policies may require an endorsement. A statement on this certificate does not confer rights to the certificate holder in lieu of such endorsement(s).

PRODUCER VTC Insurance Group 37000 Grand River Ave Ste 150 Farmington Hills MI 48335	CONTACT NAME: Deborah Gale PHONE (A/C, No, Ext): (248) 888-0370 FAX (A/C, No): E-MAIL: dgale@vtcins.com ADDRESS: INSURER(S) AFFORDING COVERAGE INSURER A: Nautilus Insurance Company INSURER B: Charter Oak Fire Insurance INSURER C: Great Divide Insurance Company INSURER D: INSURER E: INSURER F:
INSURED Environmental Maintenance Engineers, Inc. 25851 Trowbridge Inkster MI 48141	NAIC # 17370 25615 25224

COVERAGES

CERTIFICATE NUMBER: 21-22 Liab

REVISION NUMBER:

THIS IS TO CERTIFY THAT THE POLICIES OF INSURANCE LISTED BELOW HAVE BEEN ISSUED TO THE INSURED NAMED ABOVE FOR THE POLICY PERIOD INDICATED. NOTWITHSTANDING ANY REQUIREMENT, TERM OR CONDITION OF ANY CONTRACT OR OTHER DOCUMENT WITH RESPECT TO WHICH THIS CERTIFICATE MAY BE ISSUED OR MAY PERTAIN, THE INSURANCE AFFORDED BY THE POLICIES DESCRIBED HEREIN IS SUBJECT TO ALL THE TERMS, EXCLUSIONS AND CONDITIONS OF SUCH POLICIES. LIMITS SHOWN MAY HAVE BEEN REDUCED BY PAID CLAIMS.

INSR LTR	TYPE OF INSURANCE	ADDL INSD	SUBR WVD	POLICY NUMBER	POLICY EFF (MM/DD/YYYY)	POLICY EXP (MM/DD/YYYY)	LIMITS
A	☒ COMMERCIAL GENERAL LIABILITY ☐ CLAIMS-MADE ☒ OCCUR GEN'L AGGREGATE LIMIT APPLIES PER: ☐ POLICY ☒ PROJECT ☐ LOC OTHER:	X		BCP203022912	10/1/2021	10/1/2022	EACH OCCURRENCE \$ 2,000,000 DAMAGE TO RENTED PREMISES (Ea occurrence) \$ 100,000 MED EXP (Any one person) \$ 5,000 PERSONAL & ADV INJURY \$ 2,000,000 GENERAL AGGREGATE \$ 2,000,000 PRODUCTS - COMP/OP AGG \$ 2,000,000
B	AUTOMOBILE LIABILITY ☒ ANY AUTO ALL OWNED AUTOS ☒ HIRED AUTOS ☐ SCHEDULED AUTOS NON-OWNED AUTOS			BA0135C519	10/1/2021	10/1/2022	COMBINED SINGLE LIMIT (Ea accident) \$ 1,000,000 BODILY INJURY (Per person) \$ BODILY INJURY (Per accident) \$ PROPERTY DAMAGE (Per accident) \$
A	UMBRELLA LIAB ☒ OCCUR EXCESS LIAB ☐ CLAIMS-MADE DED RETENTION \$			FFX203023112	10/1/2021	10/1/2022	EACH OCCURRENCE \$ 3,000,000 AGGREGATE \$ 3,000,000
C	WORKERS COMPENSATION AND EMPLOYERS' LIABILITY ANY PROPRIETOR/PARTNER/EXECUTIVE OFFICER/MEMBER EXCLUDED? (Mandatory in NH) If yes, describe under DESCRIPTION OF OPERATIONS below	Y/N ☐	N/A	WCA203020812	10/1/2021	10/1/2022	☒ PER STATUTE ☐ OTHER E.L. EACH ACCIDENT \$ 1,000,000 E.L. DISEASE - EA EMPLOYEE \$ 1,000,000 E.L. DISEASE - POLICY LIMIT \$ 1,000,000
A	Contractors Pollution Liab.			BCP203022912	10/1/2021	10/1/2022	Claims Made - Limit Each Claim: \$2,000,000
A	Professional Liability			BCP203022912	10/1/2021	10/1/2022	Claims Made - Limit Each Claim: \$2,000,000

DESCRIPTION OF OPERATIONS / LOCATIONS / VEHICLES (ACORD 101, Additional Remarks Schedule, may be attached if more space is required)

Project: Community and Burns Park Where required by written contract, Ann Arbor Public Schools, its officers, officials, employees, and volunteers are additional insured on the CGL policy with respect to liability arising out of work or operations performed by or on behalf of the Contractor including materials, parts or equipment furnished in connection with such work or operations. It is understood and agreed that thirty (30) days advance notice of cancellation, non-renewal, reduction.

CERTIFICATE HOLDER

Finance Department Ann Arbor Public Schools 2555 S. State Street Ann Arbor, MI 48104	CANCELLATION SHOULD ANY OF THE ABOVE DESCRIBED POLICIES BE CANCELLED BEFORE THE EXPIRATION DATE THEREOF, NOTICE WILL BE DELIVERED IN ACCORDANCE WITH THE POLICY PROVISIONS. AUTHORIZED REPRESENTATIVE P Williams/DGALE
---	--

© 1988-2014 ACORD CORPORATION. All rights reserved.

Juneau Property Maintenance

870 Capitol Ave., Lincoln Park, Michigan 48146 (313) 383-1468

Brad Altherr

XXX-XX-XX

Has successfully completed a Michigan and EPA approved course in accordance with Title II of the Toxic Substance Control Act, 40 CFR 763 (AHERA) as amended 1994, MI P.A. 440 of 1988 as amended and 40 CFR Part 61 (NESHAP Revision).

FOR:

EIGHT (8) - HOUR REFRESHER ASBESTOS ABATEMENT TRAINING FOR WORKERS

Course Dates: May 15, 2021

Certificate Number: WR-2021 0005

Expiration Date: May 15, 2022

Jim Watts

Jim Watts, Instructor

Training Location: 870 Capitol Ave; Lincoln Park, MI

State of Michigan

Department of Labor and Economic Opportunity

Michigan Occupational Safety & Health Administration - Asbestos Program

Asbestos Abatement Worker

Bradley F. Altherr



Accreditation Number

A45730

Expiration Date

06/04/2022

DOB:

This individual has satisfactorily met or exceeded the requirements of Section 206 of the Toxic Substances Control Act to be accredited in the above discipline.

Expiration date is valid
valid if altered

152926



Environmental Maintenance Engineers, Inc.
25851 Trowbridge St. Inkster, MI 48141
313.791.2600 Office - 313.701.2601 Fax
www.teameme.com

Qualitative Fit Testing Record

Bradley Altherr

Employee Name

7/15/2021

Date of Test

7/15/2022

Expiration Date

1) Have you had any respiratory problems in the last week?

☐ Yes ☒ No

2) Testing agent used: Irritant Smoke

☐ Yes ☐ No

3) Employee sensitive?

☒ Yes ☐ No

4) Positive - Negative facepiece to face test passed?

☒ Yes ☐ No

5) Qualitative Fit Test passed?

☒ Yes ☐ No

Tester Signature:

Date: 7/15/2021

Tester Printed Name:

David Silva

Approved Respirator(s):

Size:

☐ Small

☒ Medium

☒ Large

1) Brand: Morguard M44

Model #: RU 8822

Type: 3/4 In.

2) Brand: _____

Model #: _____

Type: _____

Respiratory Protection Training Program:

Before signing, be sure you understand each of the following items:

- 1) Explanation of the ramifications of misuse
- 2) Why the particular respirator was selected
- 3) Limitations of the selected respirator
- 4) Putting on the respirator
- 5) Wearing the respirator
- 6) Maintenance of the respirator
- 7) Recognize & handling emergency situations
- 8) Inspecting the respirator
- 9) Use of air purifying respirator
- 10) Purpose of medical evaluation
- 11) Proper fit-testing techniques

I understand the use, care and inspection of the respirator(s) I may use.

I have had the opportunity to wear and fit-test the respirator(s) I use.

Employee Signature

7/15/2021

Date

OSHA Physician Written Opinion for Asbestos Medical Surveillance in accordance with CFR Part 1910.1001 (1)(7)

The following individual has been examined in accordance with the Occupational Safety and Health Administration (OSHA) Asbestos Construction Standard, 29 CFR 1910.1001:

Name of individual:

Date of Examination:

Name of Examining Physician:

Name of Medical Facility:

Address of Medical Facility:

Phone Number of Facility:

In accordance with the requirements of Section (f) of the OSHA Asbestos standard, 29 CFR 1910.1001, the examining physician will provide the employee with a written opinion which shall contain the following: (the physician must check a box for each statement below)

1. Based on the results of the medical examination, I have determined this individual

☒ May or ☐ May NOT use a respirator while performing asbestos work

2. Recommended limitations for respirator use if any:

☐ Use of Respirator is conditional upon passing a respirator fit test

☐ Remove facial hair which interferes with respirator fit

☐ No oil/wax contact lenses while using respirator

☐ Corrective lenses worn with the shall be worn so as not to adversely affect the fit of the face piece

3. The results of my examination today

☐ Have or ☐ Have NOT detected a medical condition which would place the employee at an increased risk of material health impairment from exposure to asbestos.

4. ☐ HAVE informed the above-named individual of the results of the medical examination and of any medical conditions that may result from asbestos exposure

5. ☐ The employee HAS been advised of the increased risk of lung cancer attributable to the combined effect of smoking and asbestos exposure

6. An attending physician, I have determined that a Chest Roentgenogram (X-Ray) ☐ WAS NOT NECESSARY ☐ WAS NECESSARY and performed

The complete medical examination report on the above-named individual will be forwarded to the employer pending conclusion and interpretation of any additional testing performed during the examination

Signature of Examining Physician

Date

5-14-21

Juneau Property Maintenance

870 Capitol Ave., Lincoln Park, Michigan 48146 (313) 383-1468

Nathaniel Hill

XXX-XX-

Has successfully completed a Michigan and EPA approved course in accordance with Title II of the Toxic Substance Control Act, 40 CFR 763 (ASHERA) as amended 1994, MI P.A. 440 of 1988 as amended and 40 CFR Part 61 (NESHAP Revision).

**FOR:
EIGHT (8) - HOUR REFRESHER ASBESTOS ABATEMENT TRAINING FOR
CONTRACTORS AND SUPERVISORS**

Course Dates: November 28, 2021

Certificate Number: CSR-2021 0266

Expiration Date: November 28, 2022

Jim Watts

Training Location: 870 Capitol Ave., Lincoln Park, MI

Jim Watts, Instructor

State of Michigan

Department of Labor and Economic Opportunity

Michigan Occupational Safety & Health Administration - Asbestos Program



Asbestos Contractor/Supervisor

Nathaniel N. Hill



Accreditation Number

A30676

Expiration Date

03/11/2023

DOB:

This individual has satisfactorily met or exceeded the requirements of Section 206 of the Toxic Substances Control Act to be accredited in the above discipline.

Accreditation card is not
valid if altered

156179



Environmental Maintenance Engineers, Inc.
25851 Trowbridge St., Inkster, MI 48141
313.791.2600 Office - 313.701.2601 Fax
www.teameme.com

Qualitative Fit Testing Record

7/15/2021

Date of Test

7/15/2022

Expiration Date

Nathaniel Hill

Employee Name

1) Have you had any respiratory problems in the last week?

☐ Yes ☒ No

2) Testing agent used: Irritant Smoke

☐ Yes ☐ No

3) Employee sensitive?

☒ Yes ☐ No

4) Positive - Negative facepiece to face test passed?

☒ Yes ☐ No

5) Qualitative Fit Test passed?

☒ Yes ☐ No

Tester Signature: [Signature]

Date: 7/15/2021

Tester Printed Name: David Silva

Approved Respirator(s):

Size: ☐ Small ☒ Medium ☒ Large

1) Brand: Harquest / Minut

Model #: RV 8800

Type: 1/2 face

2) Brand: _____

Model #: _____

Type: _____

Respiratory Protection Training Program:

Before signing, be sure you understand each of the following items:

- 1) Explanation of the ramifications of misuse
- 2) Why the particular respirator was selected
- 3) Limitations of the selected respirator
- 4) Putting on the respirator
- 5) Wearing the respirator
- 6) Maintenance of the respirator
- 7) Recognize & handling emergency situations
- 8) Inspecting the respirator
- 9) Use of air purifying respirator
- 10) Purpose of medical evaluation
- 11) Proper fit-testing techniques

I understand the use, care and inspection of the respirator(s) I may use.
I have had the opportunity to wear and fit-test the respirator(s) I use.

[Signature]

Employee Signature

7/15/2021

Date

v-62016

Test valid for 1 year from date of test

OSHA Physician Written Opinion for Asbestos Medical Surveillance In accordance with CFR Part 1910.1001 (1)(7)

The following individual has been examined in accordance with the Occupational Safety and Health Administration (OSHA) Asbestos Construction Standard, 29 CFR 1910.1001:

Name of Individual: Nathaniel Hill
Date of Examination: 8/19/2021
Name of Examining Physician: L. Robinson, MD
Name of Medical Facility: 1st Choice Urgent Care
Address of Medical Facility: 31450 Ford Rd
Garden City, MI 48135
Phone Number of Facility: 734-333-8001

In accordance with the requirements of Section (f) of the OSHA Asbestos standard, 29 CFR 1910.1001, the examining physician will provide the employer with a written opinion which shall contain the following: (the physician must check a box for each statement below)

1. Based on the results of the medical examination, I have determined this individual:

☒ May or ☐ May NOT use a respirator while performing asbestos work

2. Recommended limitations for respirator use if any:

☒ Use of Respirator is conditional upon passing a respirator fit test

☐ Remove facial hair which interferes with respirator fit

☐ Do not wear contact lenses while using respirator

☐ Corrective lenses worn with the shall be worn so as not to adversely affect the fit of the face piece

3. The results of my examination today:

☐ Have or ☒ Have NOT detected a medical condition which would place the employee at an increased risk of material health impairment from exposure to asbestos.

4. ☒ I HAVE informed the above-named individual of the results of the medical examination and of any medical conditions that may result from asbestos exposure.

5. ☒ The employee HAS been advised of the increased risk of lung cancer attributable to the combined effect of smoking and asbestos exposure.


6. As attending Physician, I have determined that a Chest Roentgenogram (X-Ray) ☐ was NOT necessary ☒ was necessary and performed.

The complete medical examination report on the above-named individual will be forwarded to the employer pending conclusion and interpretation of any additional testing performed during the examination.

Signature of Examining Physician

8/19/2021

Date



ENVIRONMENTAL, INC.

This Certifies That

Matthew Kelly

has successfully completed the


Contractor/Supervisor Refresher Course

This fulfills the requirements under TSCA Title II and is in compliance with 40 CFR 763
and Michigan Public Act 440 of 1988, as amended.

Date of Training: 05/15/2021

Date of Expiration: 05/15/2022

Certificate Number: 6069CSR0521


Instructor

Nova Environmental, Inc. 5300 Plymouth Road, Ann Arbor, Michigan 48105 (734) 930-0995

© 2005 TNA

11/01/2015

State of Michigan

Department of Labor and Economic Opportunity

Michigan Occupational Safety & Health Administration - Asbestos Program

Asbestos Contractor/Supervisor

Matthew L. Kelly

Accreditation Number

A34636

Expiration Date

07/28/2022

DOB:

This individual has satisfactorily met or exceeded the
requirements of Section 206 of the Toxic Substances
Control Act to be accredited in the above discipline.

Accreditation card is not
valid if altered

152852



Environmental Maintenance Engineers, Inc.
25851 Trowbridge St., Inkster, MI 48141
313.791.2600 Office - 313.701.2601 Fax
www.leanname.com

Qualitative Fit Testing Record

Matthew Kelly

Employee Name

7/15/2021

Date of Test

7/15/2022

Expiration Date

1) Have you had any respiratory problems in the last week?

2) Testing agent used: Irritant Smoke

3) Employee sensitive?

4) Positive - Negative facepiece to face test passed?

5) Qualitative Fit Test passed?

☐ Yes ☒ No
☐ Yes ☐ No
☒ Yes ☐ No
☒ Yes ☐ No
☒ Yes ☐ No

Tester Signature: [Signature]

Tester Printed Name: David Silva

Date: 7/15/2021

Approved Respirator(s):

Size: ☐ Small ☒ Medium ☒ Large

1) Brand: Burgess/Scott Model #: RV 8000 Type: 1/2 Gas

2) Brand: _____ Model #: _____ Type: _____

Respiratory Protection Training Program:

Before signing, be sure you understand each of the following items:

- 1) Explanation of the ramifications of misuse
- 2) Why the particular respirator was selected
- 3) Limitations of the selected respirator
- 4) Putting on the respirator
- 5) Wearing the respirator
- 6) Maintenance of the respirator
- 7) Recognize & handling emergency situations
- 8) Inspecting the respirator
- 9) Use of air purifying respirator
- 10) Purpose of medical evaluation
- 11) Proper fit-testing techniques

I understand the use, care and inspection of the respirator(s) I may use.
I have had the opportunity to wear and fit-test the respirator(s) I use.

[Signature]
Employee Signature

7/15/2021
Date

OSHA Physician Written Opinion for Asbestos Medical Surveillance in accordance with CFR Part 1910.1001 (1)(7)

The following individual has been examined in accordance with the Occupational Safety and Health Administration (OSHA) Asbestos Construction Standard, 29 CFR 1910.1001:

Name of Individual: Math Kelly

Date of Examination: 10/1/21

Name of Examining Physician: _____

Name of Medical Facility: _____

Address of Medical Facility: _____

Phone Number of Facility: _____

In accordance with the requirements of Section (f) of the OSHA Asbestos standard, 29 CFR 1910.1001, the examining physician will provide the employer with a written opinion which shall contain the following: (the physician must check a box for each statement below)

1. Based on the results of the medical examination, I have determined this individual:

☒ May or may NOT use a respirator while performing asbestos work

2. Recommended limitations for respirator use, if any:

☒ Use of Respirator is conditional upon passing a respirator fit test

☒ Remove facial hair which interferes with respirator fit

☒ Do not wear contact lenses while using respirator

☒ Corrective lenses worn with this shall be worn so as not to adversely affect the fit of the face piece

3. The results of my examination today:

☐ Have or have NOT detected a medical condition which would place the employee at an increased risk of material health impairment from exposure to asbestos

4. ☒ I HAVE informed the above-named individual of the results of the medical examination and of any medical conditions that may result from asbestos exposure

5. ☒ The employee HAS been advised of the increased risk of lung cancer attributable to the combined effect of smoking and asbestos exposure.

6. As attending Physician, I have determined that a Chest Roentgenogram (X-Ray) ☒ was NOT necessary _____ was necessary and performed.

The complete medical examination report on the above-named individual will be forwarded to the employer pending conclusion and interpretation of any additional testing performed during the examination

[Signature]
Signature of Examining Physician

Date

Juneau Property Maintenance

870 Capitol Ave., Lincoln Park, Michigan 48146 (313) 383-1468

Shane Niblock

XXX-XV-

Has successfully completed a Michigan and EPA approved course in accordance with Title II of the Toxic Substance Control Act, 40 CFR 763 (ASHERA) as amended 1994, MI P.A. 440 of 1988 as amended and 40 CFR Part 61 (NESHAP Revision).

**FOR:
EIGHT (8) - HOUR REFRESHER ASBESTOS ABATEMENT TRAINING FOR
CONTRACTORS AND SUPERVISORS**

Course Dates: October 24, 2021

Certificate Number: CSR-2021 0240

Expiration Date: October 24, 2022

Jim Watts

Training Location: 870 Capitol Ave., Lincoln Park, MI

Jim Watts, Instructor

State of Michigan

Department of Labor and Economic Opportunity

Michigan Occupational Safety & Health Administration - Asbestos Program

Asbestos Contractor/Supervisor

Shane W. Niblock

Accreditation Number
A43597

Expiration Date
12/18/2022



DOB:

This individual has satisfactorily met or exceeded the requirements of Section 206 of the Toxic Substances Control Act to be accredited in the above discipline.

Accreditation card is not
valid if altered

155353



Environmental Maintenance Engineers, Inc.
25851 Trowbridge St., Inkster, MI 48141
313.791.2600 Office - 313.701.2601 Fax
www.teameme.com

Qualitative Fit Testing Record

Shane Niblock

Employee Name

7/15/2021

Date of Test

7/15/2022

Expiration Date

1) Have you had any respiratory problems in the last week?

2) Testing agent used: Irritant Smoke

3) Employee sensitive?

4) Positive - Negative facepiece to face test passed?

5) Qualitative Fit Test passed?

☐ Yes ☒ No
☐ Yes ☐ No
☒ Yes ☐ No
☒ Yes ☐ No
☒ Yes ☐ No

Tester Signature:

Tester Printed Name: David Silva

Date: 7/15/2021

Approved Respirator(s):

Size: ☐ Small ☐ Medium ☒ Large

1) Brand: 3M 7700

Model #: 7700

Type: Fit

2) Brand: _____

Model #: _____

Type: _____

Respiratory Protection Training Program:

Before signing, be sure you understand each of the following items:

- 1) Explanation of the ramifications of misuse
- 2) Why the particular respirator was selected
- 3) Limitations of the selected respirator
- 4) Putting on the respirator
- 5) Wearing the respirator
- 6) Maintenance of the respirator
- 7) Recognize & handling emergency situations
- 8) Inspecting the respirator
- 9) Use of air purifying respirator
- 10) Purpose of medical evaluation
- 11) Proper fit-testing techniques

I understand the use, care and inspection of the respirator(s) I may use.
I have had the opportunity to wear and fit-test the respirator(s) I use.

Employee Signature

7/15/2021

Date

Test valid for 1 year from date of test

v62016

OSHA Physician Written Opinion for Asbestos Medical Surveillance In accordance with CFR Part 1910.1001 (1)(7)

The following individual has been examined in accordance with the Occupational Safety and Health Administration (OSHA) Asbestos Construction Standard, 29 CFR 1910.1001:

Name of Individual:

Shane Niblock

Date of Examination:

6/24/21

Name of Examining Physician:

Dr. David M. Hyman MD

Name of Medical Facility:

Address of Medical Facility:

Phone Number of Facility:

In accordance with the requirements of Section (f) of the OSHA Asbestos standard, 29 CFR 1910.1001, the examining physician will provide the employer with a written opinion which shall contain the following: (the physician must check a box for each statement below)

1. Based on the results of the medical examination, I have determined this individual:

___ May not ___ May not use a respirator while performing asbestos work

2. Recommended limitations for respirator use if any:

___ Use of Respirator is conditional upon passing a respirator fit test

___ Remove facial hair which interferes with respirator fit

___ Do not wear contact lenses while using respirator

___ Corrective lenses worn with the shall be worn so as not to adversely affect the fit of the face piece

3. The results of my examination today:

___ Have or ___ Have NOT detected a medical condition which would place the employee at an increased risk of material health impairment from exposure to asbestos.

4. ___ I HAVE informed the above-named individual of the results of the medical examination and of any medical conditions that may result from asbestos exposure.

5. ___ The employee HAS been advised of the increased risk of lung cancer attributable to the combined effect of smoking and asbestos exposure.


6. As attending Physician, I have determined that a Chest Roentgenogram (X-Ray) ___ was NOT necessary ___ was necessary and performed.

The complete medical examination report on the above-named individual will be forwarded to the employer pending conclusion and interpretation of any additional testing performed during the examination.

Signature of Examining Physician

Date

6/24/21



ENVIRONMENTAL, INC.

This Certifies That

Erik Richardson

has successfully completed the


Contractor/Supervisor Refresher Course

This fulfills the requirements under TSCA Title II and is in compliance with 40 CFR 763
and Michigan Public Act 440 of 1988, as amended.

Date of Training: 05/15/2021

Date of Expiration: 05/15/2022

Certificate Number: 9976CSR0521


Instructor

Nova Environmental, Inc. 5300 Plymouth Road, Ann Arbor, Michigan 48105 (734) 930-0995

© 2005 748

LITHO IN U.S.A.

State of Michigan

Department of Labor and Economic Opportunity

Michigan Occupational Safety & Health Administration - Asbestos Program

Asbestos Contractor/Supervisor

Erik GW Richardson



Accreditation Number

A52387

Expiration Date

06/05/2022

DOB:

This individual has satisfactorily met or exceeded the
requirements of Section 206 of the Toxic Substances
Control Act to be accredited in the above discipline.

152856



Environmental Maintenance Engineers, Inc.
25851 Trowbridge St., Inkster, MI 48141
313.791.2600 Office • 313.701.2601 Fax
www.eame.com

Qualitative Fit Testing Record

7/15/2021

Date of Test

7/15/2022

Expiration Date

Erik Richardson

Employee Name

1) Have you had any respiratory problems in the last week?

2) Testing agent used: Irritant Smoke

3) Employee sensitive?

4) Positive - Negative facepiece to face test passed?

5) Qualitative Fit Test passed?

☐ Yes ☒ No
☐ Yes ☐ No
☒ Yes ☐ No
☒ Yes ☐ No
☒ Yes ☐ No

Tester Signature: [Signature]

Tester Printed Name: David Silva

Date: 7/15/2021

Approved Respirator(s):

Size: Medium

1) Brand: 3M

2) Brand: 3M

☒ Large

☐ Medium

Model #:

Type: 1/2

Type:

Respiratory Protection Training Program:

Before signing, be sure you understand each of the following items:

- 1) Explanation of the ramifications of misuse
- 2) Why the particular respirator was selected
- 3) Limitations of the selected respirator
- 4) Putting on the respirator
- 5) Wearing the respirator
- 6) Maintenance of the respirator
- 7) Recognize & handling emergency situations
- 8) Inspecting the respirator
- 9) Use of air purifying respirator
- 10) Purpose of medical evaluation
- 11) Proper fit-testing techniques

I understand the use, care and inspection of the respirator(s) I may use.

I have had the opportunity to wear and fit-test the respirator(s) I use.

[Signature]

Employee Signature

7/15/2021

Date

OSHA Physician Written Opinion for Asbestos Medical Surveillance In accordance with CFR Part 1910.1001 (1)(7)

The following individual has been examined in accordance with the Occupational Safety and Health Administration (OSHA) Asbestos Construction Standard, 29 CFR 1910.1001:

Name of individual: Erik Richardson

Date of Examination: 12.3.21

Name of Examining Physician: A. Hassan MD

Name of Medical Facility: 1st Choice - DCA

Address of Medical Facility: 23455 Midway Ave

Phone Number of Facility: Deerborn MI 48124

Phone Number of Facility: 734-333-8001

In accordance with the requirements of Section (f) of the OSHA Asbestos standard, 29 CFR 1910.1001, the examining physician will provide the employer with a written opinion which shall contain the following (the physician must check a box for each statement below)

1. Based on the results of the medical examination, I have determined this individual:

☒ May or ☐ May NOT use a respirator while performing asbestos work

2. Recommended limitations for respirator use if any:

☐ Use of Respirator is conditional upon passing a respirator fit test

☐ Remove facial hair which interferes with respirator fit

☐ Do not wear contact lenses while using respirator

☐ Corrective lenses worn with the shall be worn so as not to adversely affect the fit of the face piece

3. The results of my examination today:

Have or ☒ Have NOT detected a medical condition which would place the employee at an increased risk of material health impairment from exposure to asbestos.

4. ☒ HAVE informed the above-named individual of the results of the medical examination and of any medical conditions that may result from asbestos exposure.

5. ☒ The employee HAS been advised of the increased risk of lung cancer attributable to the combined effect of smoking and asbestos exposure.

6. As attending physician, I have determined that a Chest Roentgenogram (X-ray) ☒ was NOT necessary ☐ was necessary and performed

the complete medical examination report on the above named individual will be forwarded to the employer pending conclusion and interpretation of any additional testing performed during the examination

[Signature]

Signature of Examining Physician

Date

Juneau Property Maintenance

870 Capitol Ave., Lincoln Park, Michigan 48146 (313) 383-1468

Chris Treglown

XXX-XX-

Has successfully completed a Michigan and EPA approved course in accordance with Title II of the Toxic Substance Control Act, 40 CFR 763 (AHERA) as amended 1994, MI P.A. 440 of 1988 as amended and 40 CFR Part 61 (NESHAP Revision).

FOR:

EIGHT (8) - HOUR REFRESHER ASBESTOS ABATEMENT TRAINING FOR WORKERS

Course Dates: October 30, 2021

Certificate Number: WR-2021 00028

Expiration Date: October 30, 2022

Jim Watts

Jim Watts, Instructor

Training Location: 870 Capitol Ave; Lincoln Park, MI

State of Michigan

Department of Labor and Economic Opportunity

Michigan Occupational Safety & Health Administration - Asbestos Program

Asbestos Abatement Worker



Christopher D. Treglown



Accreditation Number
A36314

Expiration Date
01/29/2023

DOB:

This individual has satisfactorily met or exceeded the requirements of Section 206 of the Toxic Substances Control Act to be accredited in the above discipline.

Accreditation card is not
valid if altered

155485



Environmental Maintenance Engineers, Inc.
25851 Trowbridge St., Inkster, MI 48141
313.781.2800 Office • 313.701.2801 Fax
www.teameme.com

Qualitative Fit Testing Record

Christopher Treglown

Employee Name

7/15/2021

Date of Test

7/15/2022

Expiration Date

1) Have you had any respiratory problems in the last week? ☐ Yes ☒ No

2) Testing agent used: Irritant Smoke ☐ Yes ☒ No

3) Employee sensitive? ☐ Yes ☒ No

4) Positive - Negative facepiece to face test passed? ☐ Yes ☒ No

5) Qualitative Fit Test passed? ☐ Yes ☒ No

Tester Signature: [Signature]

Date: 7/15/2021

Tester Printed Name: David Silva

Approved Respirator(s):

Size: ☐ Small ☐ Medium ☒ Large

1) Brand: None Model #: 7760 Type: 1/2 Full

2) Brand: _____ Model #: _____ Type: _____

Respiratory Protection Training Program:

Before signing, be sure you understand each of the following items:

- 1) Explanation of the ramifications of misuse
- 2) Why the particular respirator was selected
- 3) Limitations of the selected respirator
- 4) Putting on the respirator
- 5) Wearing the respirator
- 6) Maintenance of the respirator
- 7) Recognize & handling emergency situations
- 8) Inspecting the respirator
- 9) Use of air purifying respirator
- 10) Purpose of medical evaluation
- 11) Proper fit-testing techniques

I understand the use, care and inspection of the respirator(s) I may use.
I have had the opportunity to wear and fit-test the respirator(s) I use.

[Signature]

7/15/2021

Date

Employee Signature

v62016

Test valid for 1 year from date of test

OSHA Physician Written Opinion for Asbestos Medical Surveillance In accordance with CFR Part 1910.1001 (1)(7)

This following individual has been examined in accordance with the Occupational Safety and Health Administration (OSHA) Asbestos Construction Standard, 29 CFR 1910.1001:

Name of Individual: Christopher Treglown

Date of Examination: 1-12-22

Name of Examining Physician: M. Nehme

Name of Medical Facility: 1st Choice - Dearborn

Address of Medical Facility: 23455 Michigan Ave

Phone Number of Facility: Dearborn, MI 48135

Phone Number of Facility: 313-438-6094

In accordance with the requirements of Section (f) of the OSHA Asbestos standard, 29 CFR 1910.1001, the examining physician will provide the employer with a written opinion which shall contain the following: (the physician must check a box for each statement below)

1. Based on the results of the medical examination, I have determined this individual:

- ☒ May or may NOT use a respirator while performing asbestos work
2. Recommended limitations for respirator use if any:
- ☒ Use of Respirator is conditional upon passing a respirator fit test
- ☒ Remove facial hair which interferes with respirator fit
- ☒ Do not wear contact lenses while using respirator
- ☒ Corrective lenses worn with the shall be worn so as not to adversely affect the fit of the face piece

3. The results of my examination today:

☒ Have or have NOT detected a medical condition which would place the employee at an increased risk of material health impairment from exposure to asbestos.

4. ☒ I HAVE informed the above-named individual of the results of the medical examination and of any medical conditions that may result from asbestos exposure.

5. ☒ The employee HAS been advised of the increased risk of lung cancer attributable to the combined effect of smoking and asbestos exposure.

6. As attending physician, I have determined that a Chest Roentgenogram (X-ray) was NOT necessary g was necessary and performed.

The complete medical examination report on the above named individual will be forwarded to the employer pending conclusion and interpretation of any additional testing performed during the examination.

[Signature]

Signature of Examining Physician

1-12-22

Date

Michigan Department of Natural Resources Air Quality Division



Check here if dumpster is located
on a jobsite (not at the office)

Internal Job #: 22-025

Landfill Approval #: 30691314442

ASBESTOS WASTE SHIPMENT DOCUMENT

1) Worksite name & address: Community High School 401 N. Division Street Ann Arbor, MI 48104	Owner's Name: Ann Arbor Public Schools 2555 South State St Ann Arbor, MI 48104	Contact Name Roosevelt Austin III Contact Telephone # (734) 576-0765
--	--	---

2) Operator's Name: Environmental Maintenance Engineers, Inc.	Operator's Address: 25851 Trowbridge Inkster, MI 48141	Operator's Telephone #: (313) 791-2600
---	---	--

3) Waste Disposal Site (WDS) Name: Carleton Farms Landfill	Waste Disposal Mailing Address: 28800 Clark Rd. New Boston, MI 48164	Disposal Site Telephone #: (734) 654-0001
--	---	---

4) Responsible Agency: Air Quality Division, Michigan Department of Natural Resources P.O. Box 30028 Lansing, MI 48909
--

5) Description of Materials:		
Hazard Class: 9	Identification Number: NA2212	Packing Group: III
Additional Description:		

6) Containers:			
	# of Containers:	Type of Containers (drums, bags, etc)	Total Qty. (cu ft., cu yds., lbs., tons):
☐ Friable Asbestos			
☐ Non-Friable Asbestos	8	Bags	
☐ Other:			

7) Special Handling Instructions and Additional Information: Handled in accordance with all EPA, NESHAP, & OSHA Regulations	
---	--

8) Operator's Certification: I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway condition for transport by highway according to applicable international and government regulations.	
Printed/Typed Name: Jeff Cheney	Title: Project Manager
Signature:	Date: 2-19-2022

9) Transporter (Acknowledgement of Receipt of Materials):	
Name: Environmental Maintenance Engineers, Inc.	
Address: 25851 Trowbridge, Inkster, MI 48141	Phone Number: (313) 791-2600
Printed/Typed Name: Susan Niblack	Title: Supervisor
Signature:	Date: 02/19/22

10) Transporter 2 (Acknowledgement of Receipt of Materials):	
Name: Republic Services - Wayne	
Address: 5400 Cogswell, Wayne, MI 48184	Phone Number: (734) 216-8240
Printed/Typed Name: C. Roberts	Title: Driver
Signature:	Date:

11) Waste disposal site owner or operator: Certification of receipt of asbestos materials covered by this manifest except as noted in item 10.	
Printed/Typed Name:	Title:
Signature:	Date: 2-25-22



25 YEARS
1997 - 2022

25851 Trowbridge St., Inkster, MI 48141
Voice: 313.791.2600 Fax: 313.791.2601 www.teamEME.com

Today's Date/Day:

S M T W T F S 02/18/22

Job #:

22-025

Week Ending Date:

02/20/22

Job Name:

Community H.S.

Truck #/Driver:

42 / BRAND / SUANE

ACM Mold / Lead / Other

Work Area:

1ST FLOOR STAIRWELL / CORRIDOR

Comments:

2ND FLOOR CORRIDOR

Daily Construction Report

General Work Description:

	Y	N	n/a
ACM Pipe/Fitting			
ACM Boiler/Tanks/Breeching			
ACM Acoustical Ceiling			
ACM Ceiling Tiles/Glue Pods			
VAT Mastic Carpet			
Transite Siding/			
Insulation/Vermiculite			
Lead Based Paint			
Mold Remediation			
Industrial/Universal Waste			
Other			

The type of abatement conducted:

	Y	N	n/a
Removal			
Encapsulation			
Patch/Repair			
Glove-bag Removal			
Enclosure			
Removal/Replacement			
LBP Removal Chemical			
LBP HEPA Power Tools			
Dry Ice Blasting			
Aggressive Hand Cleaning			
Selective Demolition			

Set-up procedures conducted:

	Y	N	n/a
Signs/Banner Tape			
Criticals Set-up			
Full/Mini Enclosure			
Plywood 2"x4" Structures			
AFD's Set-up Vented			
Isolation of HVAC system			
Poly Walls Floors Drops			
Portable/Full Decon Chamber			
Water System Set-up			
Electric GFCI's/Temp. Panel			
Scaffold/Bakers/5'x7'/Manlift			

Personal protective equipment:

	Y	N	n/a
Respiratory protection			
Half-Face/Full-Face/PAPR's			
Disposable Suits			
Steel Toe/Rubber Boots			
Gloves Rubber/Cotton			
Safety Glasses/Full Face			
Hard hats/Hearing Protection			
Fall Protection			
Scaffold Safety Rails/Manlift			

Clean-up activities:

	Y	N	n/a
Gross/Final Clean-up			
Load Out Activities			
Surfactants/Ledizolv			
Wet Methods IAQ Shockwave			
HEPA Vacuum Sequence			
All Equip./Tools Cleaned			
Final Lockdown			
Work Area Teardown			
Final Worksite Walk-Thru			

Inspections:

	Y	N	n/a
# of Neg. Air Machines			
Barriers Intact And Sound			
DECON/Shower Inspection			
Employee PPE Used			
Electrical Safety In Place			
OSHA Inspection Site Review			
Consultant/EME Monitoring			
Consultant/Supervisor Visual			
Personnel Decontaminated			
Work Area Inspected/Secure			

Consultant Firm: AQL

Representative Name: ERIC

Visual/Testing: AIR / VISUAL

Accreditation Number:

Manometer Readings	Start:	inches water	Middle:	inches water	End:	inches water	Notes:
--------------------	--------	--------------	---------	--------------	------	--------------	--------

Employee Name	Accred. #	Class SW	Time In	Time Out	Time In	Time Out	Total Hrs	Employee Signature
Project Manager:								
Supervisor:								
SUANE NIELOCK	A13597	S	1:30	-	-	11:00	9.5	
BRAND ALTHEER	A45730	W	5:00	-	-	12:00	7.0	
CHRIS TRELOAWN	A36314	W	5:00	-	-	11:00	6.0	

Safety Issues: LOAD OUT, SLIP/TRIP HAZ, PAKER, LADDERS, POWER - TOOLS	Asbestos Waste	Dumpster	EME	Onsite
	---Friable---	---Non-Friable---	Status of Job	
	Bags	Bags	Project On-going - someone to return	
	Drums	Drums	Note:	
	Bundles	Bundles	Complete - no one will need to return	

I certify area has been visually inspected, all equipment is off site and there is no debris or other materials left.

Signature: _____



**ENVIRONMENTAL
MAINTENANCE
ENGINEERS, INC.**

25 YEARS
1997 - 2022

25851 Trowbridge St., Inkster, MI 48141
Voice: 313.791.2600 Fax: 313.791.2601 www.teamEME.com

Today's Date/Day:

S M T W T F S

02/19/22

Job #:

22-025

Week Ending Date:

02/20/22

Job Name:

Community H.S.

Truck #/Driver:

49 / NATE H

ACM

Mold / Lead / Other

Work Area:

1ST FLOOR STAIRWELL / CORRIDOR

Comments:

2ND FLOOR CORRIDOR

Daily Construction Report

General Work Description:

	Y	N	n/a
ACM Pipe/Fitting			
ACM Boiler/Tanks/Breeching			
ACM Acoustical Ceiling			
ACM Ceiling Tiles/Glue Pods			
VAT Mastic Carpet			
Transite Siding/			
Insulation/Vermiculite			
Lead Based Paint			
Mold Remediation			
Industrial/Universal Waste			
Other			

The type of abatement conducted:

	Y	N	n/a
Removal			
Encapsulation			
Patch/Repair			
Glove-bag Removal			
Enclosure			
Removal/Replacement			
LBP Removal Chemical			
LBP HEPA Power Tools			
Dry Ice Blasting			
Aggressive Hand Cleaning			
Selective Demolition			

Set-up procedures conducted:

	Y	N	n/a
Signs/Banner Tape			
Criticals Set-up			
Full/Mini Enclosure			
Plywood 2"x4" Structures			
AFD's Set-up Vented			
Isolation of HVAC system			
Poly Walls Floors Drops			
Portable/Full Decon Chamber			
Water System Set-up			
Electric GFCI's/Temp. Panel			
Scaffold/Bakers/5'x7'/Manlift			

Personal protective equipment:

	Y	N	n/a
Respiratory protection			
Half-Face/Full-Face/PAPR's			
Disposable Suits			
Steel Toe/Rubber Boots			
Gloves Rubber/Cotton			
Safety Glasses/Full Face			
Hard hats/Hearing Protection			
Fall Protection			
Scaffold Safety Rails/Manlift			

Clean-up activities:

	Y	N	n/a
Gross/Final Clean-up			
Load Out Activities			
Surfactants/Ledizolv			
Wet Methods IAQ Shockwave			
HEPA Vacuum Sequence			
All Equip./Tools Cleaned			
Final Lockdown			
Work Area Teardown			
Final Worksite Walk-Thru			

Inspections:

	Y	N	n/a
# of Neg. Air Machines			
Barriers Intact And Sound			
DECON/Shower Inspection			
Employee PPE Used			
Electrical Safety In Place			
OSHA Inspection Site Review			
Consultant/EME Monitoring			
Consultant/Supervisor Visual			
Personnel Decontaminated			
Work Area Inspected/Secure			

Consultant Firm: ARCH

Representative Name: THINH

Visual/Testing: AIR / VISUAL

Accreditation Number:

Manometer Readings Start: - inches water Middle: - inches water End: - inches water Notes:

Employee Name	Accred. #	Class S/W	Time In	Time Out	Time In	Time Out	Total Hrs	Employee Signature
Project Manager:								
Supervisor:								
GUANE NIBUOK	A43597	S	8:00	-	-	4:30	8.5	
BRAND ALTHERR	A45730	W	7:00	-	-	3:30	8.0	
ERIK RICHARDSON	A52325	W	8:00	-	-	3:30	7.0	
MATT KELLY	A34634	W	8:00	-	-	11:30	3.5	
NATE HILL	A30676	W	7:00	-	-	11:30	4.5	

Safety Issues: POWER TOOLS, BAKERS,

LADDERS, LOAD OUT, SLIP/TRIP-

HAZ

Asbestos Waste

--Friable--

--Non-Friable--

Dumpster

EME

Onsite

Status of Job

Bags

8

Bags

Project On-going - someone to return

Drums

Drums

Note:

Bundles

Bundles

Complete - no one will need to return

I certify area has been visually inspected, all equipment is off site and there is no debris or other materials left.

Signature: