



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Abbot Elementary School							
Date of Sampling: 10/20/2018							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Abbot-05	Kitchen, 3-compartment Sink, Right Faucet	KF	1:26 PM	5	8	Y	First Draw
Abbot-14	Room D-7, Faucet, Corner of Room	C	2:20 PM	5	16	Y	First Draw
Abbot-20	Room D-7, Bubbler, Corner of Room	C	2:18 PM	5	16	N	First Draw

Abbot Elementary School							
Date of Sampling: 10/27/2018							
Sampler: Jenna Sendra							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Abbot-04	Food Prep Kitchen, Sprayer	KF	10:31 AM	5	ND	N	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Abbot Elementary School							
Date of Sampling: 12/22/2018							
Sampler: Jenna Sendra							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Abbot-05	Kitchen, 3-compartment Sink, Right Faucet	KF	9:08 AM	5	2	Y	Follow-Up First Draw Following Replacement
Abbot-14	Room D-7, Faucet, Corner of Room	C	9:14 AM	5	34	Y	Follow-Up First Draw Following Replacement
Abbot-20	Room D-7, Bubbler, Corner of Room	C	Did not sample, water flow too low.				

Abbot Elementary School							
Date of Sampling: N/A							
Sampler: N/A							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Abbot-04	Food Prep Kitchen, Sprayer	KF	Location Determined to be Nonpotable and Marked as "Food Prep Only"				
Abbot-14	Room D-7, Faucet, Corner of Room	C	Location Permanently Removed				
Abbot-20	Room D-7, Bubbler, Corner of Room	C	Location Permanently Removed				

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested