



Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Abbot-05	Kitchen, 3-compartment Sink, Right Faucet	KF	1:26 PM	5	8	Y	First Draw
Abbot-13	Hallway, Next to Gym, Across from Teacher's Lounge, Hydration Station Bottle Fill	BT	1:29 PM	5	ND ³	Y	First Draw
Abbot-14	Room D-7, Faucet, Corner of Room	C	2:20 PM	5	16	Y	First Draw
Abbot-15	Room D-6, Island Near Door, Bubbler	C	2:10 PM	5	1	N	First Draw
Abbot-16	Room D-7, Island Near Door, Bubbler	C	2:12 PM	5	ND	N	First Draw
Abbot-17	D Hall Centrum, Bubbler	C	2:00 PM	5	1	N	First Draw
Abbot-18	D Hall Centrum, Faucet	C	11:59 PM	5	ND	Y	First Draw
Abbot-19	Room C-10, Faucet	F	1:53 PM	5	3	Y	First Draw
Abbot-20	Room D-7, Bubbler, Corner of Room	C	2:18 PM	5	16	N	First Draw
Abbot-21	Room D-7, Island Near Door, Faucet	C	2:17 PM	5	1	Y	First Draw
Abbot-22	Room D-6, Corner of Room, Bubbler	C	2:15 PM	5	4	N	First Draw
Abbot-23	Room D-6, Corner of Room, Faucet	C	2:16 PM	5	4	Y	First Draw
Abbot-24	Room C-6, Bubbler	B	1:51 PM	5	2	N	First Draw
Abbot-25	Room C-7, Bubbler	B	1:50 PM	5	3	N	First Draw
Abbot-26	Room C-8, Bubbler	B	1:46 PM	5	2	N	First Draw
Abbot-27	Hallway, Next to Room C-8, Faucet	C	1:43 PM	5	2	N	First Draw
Abbot-28	Office Workroom, Faucet	F	1:36 PM	5	1	Y	First Draw
Abbot-29	Nurse's Clinic, Faucet	F	1:34 PM	5	ND	Y	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Abbot-30	Room A-3, Bubblers	B	12:40 PM	5	1	N	First Draw
Abbot-31	Room D-6, Island Near Door, Bubblers	C	2:14 PM	5	1	Y	First Draw
Abbot-32	Room A-5, Bubblers	B	1:06 PM	5	1	N	First Draw
Abbot-33	Room A-6, Bubblers	B	1:08 PM	5	2	N	First Draw
Abbot-34	Room A-7, Bubblers	B	1:15 PM	5	3	N	First Draw
Abbot-35	Room A-8, Bubblers	B	1:14 PM	5	1	N	First Draw
Abbot-36	A Hall Centrum, Faucet	C	1:10 PM	5	ND	Y	First Draw
Abbot-37	Room A-10, Bubblers	B	1:12 PM	5	1	N	First Draw
Abbot-38	A Hall Centrum, Bubblers	C	Not Sampled				Low Flow, No Sample Collected.

1) Type: B = Bubblers, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Abbot-01	Hallway, Next to Gym, Across from Teacher's Lounge, Bottle Fill, Water Cooler	BT	10:18 AM	5	1	N	First Draw
Abbot-02	Office/Teachers Lounge, Kitchenette, Faucet	KF	11:03 AM	5	ND	Y	First Draw
Abbot-03	Kitchen, Single Compartment Faucet	KF	10:30 AM	5	ND	Y	First Draw
Abbot-04	Food Prep Kitchen, Sprayer	KF	10:31 AM	5	ND	N	First Draw
Abbot-06	Room B-1, Faucet	C	10:41 AM	5	2	N	First Draw
Abbot-07	Room B-1, Bubbler	C	10:42 AM	5	ND	N	First Draw
Abbot-08	Room D-2, Bubbler	B	10:50 AM	5	2	N	First Draw
Abbot-09	Room D-3, Bubbler	B	10:52 AM	5	2	N	First Draw
Abbot-10	Room D-4, Bubbler	B	10:55 AM	5	3	N	First Draw
Abbot-11	Room D-5, Bubbler	B	10:56 AM	5	2	N	First Draw
Abbot-12	Hallway, Next to Room C-8, Bubbler	C	10:46 AM	5	2	N	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Abbot-38	A Hall Centrum, Bubblers	C	8:36 AM	5	ND	N	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested