



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Community High School							
Date of Sampling: 3/29/2019							
Sampler: Jessica Perfetti							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Community-01	Main Office, Second Floor, Staff Single Sink	F	1:35 PM	5	2	Y	First Draw
Community-02	Hallway, Outside Room 212, Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Community-03	Hallway, Outside Room 310, Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Community-05	Hallway, Outside Room 306, Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Community-06	Hallway, Outside Room 303, Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Community-07	Hallway, Outside Room 315, Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Community-08	Hallway, Outside Room 213, Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Community-09	Clinic, Second Floor, Kitchen Faucet	KF	1:49 PM	5	ND ³	Y	First Draw
Community-11	Hallway, Outside Room 118, Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Community-12	Hallway, Across from Room 111, Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Community-19	Kitchen, 3-Compartment Sink, Left Faucet	KF	1:25 PM	5	3	Y	First Draw
Community-20	Kitchen, 3-Compartment Sink, Right Faucet	KF	1:26 PM	5	2	Y	First Draw

1) Type: B = Bubble, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plummed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Community High School							
Date of Sampling: 5/4/2019							
Sampler: Kellie Das							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Community-02	Hallway, Outside Room 212, Hydration Station, Water Cooler	BT	12:33 PM	5	ND	N	First Draw, Newly Added Hydration Station
Community-03	Hallway, Outside Room 310, Hydration Station, Water Cooler	BT	1:00 PM	5	ND	N	First Draw, Newly Added Hydration Station
Community-04	Hallway, Outside Room 310, Hydration Station, Bottle Fill	BT	1:01 PM	5	ND	N	First Draw, Newly Added Hydration Station
Community-05	Hallway, Outside Room 306, Water Cooler	WC	12:56 PM	5	ND	N	First Draw
Community-06	Hallway, Outside Room 303, Hydration Station, Water Cooler	BT	12:52 PM	5	ND	N	First Draw, Newly Added Hydration Station
Community-07	Hallway, Outside Room 315, Hydration Station, Water Cooler	BT	12:48 PM	5	ND	N	First Draw, Newly Added Hydration Station
Community-08	Hallway, Outside Room 213, Hydration Station, Water Cooler	BT	12:41 PM	5	ND	N	First Draw, Newly Added Hydration Station
Community-10	Hallway, Outside Room 303, Hydration Station, Bottle Fill	BT	12:53 PM	5	ND	N	First Draw, Newly Added Hydration Station
Community-11	Hallway, Outside Room 118, Hydration Station, Water Cooler	BT	12:28 PM	5	ND	N	First Draw, Newly Added Hydration Station
Community-12	Hallway, Outside Room 111, Hydration Station, Water Cooler	BT	12:20 PM	5	ND	N	First Draw, Newly Added Hydration Station
Community-13	Media Center, Single Sink	BT	12:38 PM	5	1	Y	First Draw, Newly Added Hydration Station
Community-14	Hallway, Outside Room 118, Hydration Station, Bottle Fill	BT	12:29 PM	5	ND	N	First Draw, Newly Added Hydration Station
Community-15	Hallway, Outside Room 212, Hydration Station, Bottle Fill	BT	12:34 PM	5	ND	N	First Draw, Newly Added Hydration Station
Community-16	Hallway, Outside Room 213, Hydration Station, Bottle Fill	BT	12:42 PM	5	ND	N	First Draw, Newly Added Hydration Station

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/you-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861

Community High School							
Date of Sampling: 5/4/2019							
Sampler: Kellie Das							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Community-17	Hallway, Across from Room 111, Hydration Station, Bottle Fill	BT	12:21 PM	5	ND	N	First Draw, Newly Added Hydration Station
Community-18	Hallway, Outside Room 315, Hydration Station, Bottle Fill	BT	12:49 PM	5	ND	N	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
2) <https://www.epa.gov/you-drinking-water/table-regulated-drinking-water-contaminant>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested