



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Eberwhite Elementary School							
Date of Sampling: March 30, 2019							
Sampler: Jenna Sendra							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Eberwhite-05	Room 115, Single Sink Faucet	F	9:35 AM	5	10	Y	IFD, after school wide corrective activities.
Eberwhite-28	Room 133, Combination Sink Faucet	C	10:59 AM	5	440	Y	IFD, after school wide corrective activities.
Eberwhite-48	Room 125, Combination Sink Faucet	C	9:48 AM	5	120	Y	IFD, after school wide corrective activities.
Eberwhite-52	Room 102, Combination Sink Faucet	C	8:26 AM	5	49	Y	IFD, after school wide corrective activities.

Eberwhite Elementary School							
Date of Sampling: April 6, 2019							
Sampler: Alec Staber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Eberwhite-05	Room 115, Single Sink Faucet	F	10:53 AM	5	6	Y	Follow-up sampling after additional cleaning and flushing.
Eberwhite-28	Room 133, Combination Sink Faucet	C		5	3	Y	Follow-up sampling after additional cleaning and flushing.
Eberwhite-48	Room 125, Combination Sink Faucet	C		5	1	Y	Follow-up sampling after additional cleaning and flushing.
Eberwhite-52	Room 102, Combination Sink Faucet	C		5	5	Y	Follow-up sampling after additional cleaning and flushing.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Eberwhite Elementary School							
Date of Sampling: May 4, 2019							
Sampler: Kellie Miller							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Eberwhite-05	Room 115, Single Sink Faucet	F	2:00 PM	5	7	Y	2nd Follow-up sampling after additional cleaning and flushing.

Eberwhite Elementary School							
Date of Sampling: May 8, 2019							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Eberwhite-05	Room 115, Single Sink Faucet	F					Placed a "Hand Wash Only- No Drinking" Sign at Location

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminante>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested