



Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Forsythe-01	Room 112, Wood Shop, Combination Sink Bubbler	C	Not Sampled.				Low Flow.
Forsythe-02	Room 112, Wood Shop, Combination Sink Faucet	C	1:26 PM	5	3	Y	First Draw. Sink dirty with paint.
Forsythe-04	Room 113 Bubbler	B	1:25 PM	5	1	N	First Draw, Corrosion.
Forsythe-05	Room 111 Bubbler	B	1:22 PM	5	1	N	First Draw
Forsythe-06	Room 103 Faucet	F	1:18 PM	5	9	N	First Draw, Corrosion.
Forsythe-07	Hallway, Outside Room 110 & Gym Annex, Hydration Station, Bottle Fill	BT	1:29 PM	5	ND ³	N	First Draw
Forsythe-08	Kitchen, 3-Compartment Sink, Right Faucet	KF	1:15 PM	5	4	Y	First Draw
Forsythe-09	Auditorium Lobby, Left Single Water Cooler	WC	1:45 PM	5	ND		First Draw
Forsythe-10	Kitchen, 3-Comp Sink, Left Faucet	KF	1:16 PM	5	3	N	First Draw
Forsythe-11	Hallway, Outside Room 110 & Gym Annex, Hydration Station, Water Cooler	BT	1:29 PM	5	ND	N	First Draw
Forsythe-12	Cafeteria, Combination Bottle Fill Outlet	BT	1:13 PM	5	1	N	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminante>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes	
Forsythe-13	Cafeteria, Combination Bubbler Outlet	BT	1:12 PM	5	ND	N	First Draw	
Forsythe-14	Room 310, Right Faucet	F	1:5 1PM	5	2	Y	First Draw, Leaky.	
Forsythe-15	Room 310, Left Faucet	F	1:50 PM	5	2	Y	First Draw	
Forsythe-16	Hallway, Outside Cafeteria, Water Cooler	WC	Not Sampled.					Scheduled to be replaced with a Hydration Station.
Forsythe-17	Hallway inside Conference Room Wing, Faucet	F	1:54 PM	5	ND	Y	First Draw	
Forsythe-18	Hallway, Outside Room 401, Bubbler	B	Not Sampled.					Scheduled to be replaced with a Hydration Station.
Forsythe-19	Hallway, Outside Room 412, Bubbler	B	Not Sampled.					Scheduled to be replaced with a Hydration Station.
Forsythe-20	Hallway, Outside Room 603, Hydration Station, Bottle Fill	BT	1:58 PM	5	ND	N	First Draw. New Hydration Station.	
Forsythe-21	Across From Room 612, Faucet	F	2:01 PM	5	ND	Y	First Draw	
Forsythe-22	Hallway, Outside Room 603, Hydration Station, Water Cooler	BT	1:57 PM	5	ND	N	First Draw. New Hydration Station.	
Forsythe-23	Room Across Girls Locker Room, and Adjacent to Room 325, Ice Machine	I	2:11 PM	5	ND	N	First Draw	

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminante>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Forsythe-24	Room 325, Faucet	F	2:10 PM	5	2	N	First Draw, Corrosion.
Forsythe-25	Room 323, Faucet	F	2:08 PM	5	2	Y	First Draw
Forsythe-26	Room 312, Second Island Sink Group from the Door, Left Faucet	F	2:03 PM	5	6	Y	First Draw
Forsythe-27	Room 312, Second Island Sink Group from the Door, Right Faucet	F	2:04 PM	5	11	Y	First Draw
Forsythe-28	Room 312, First Island Sink Group, Left Faucet	F	2:05 PM	5	2	N	First Draw
Forsythe-29	Room 312, First Island Sink Group, Right Faucet	F	2:06 PM	5	3	N	First Draw
Forsythe-30	Gymnasium, Outside Girls Locker Room, Bubblers	B	1:34 PM	5	ND	N	First Draw
Forsythe-31	Gymnasium, Outside Boys Locker Room, Bubblers	B	1:43 PM	5	ND	N	First Draw
Forsythe-32	Girls Locker Room, Bubblers	B	1:36 PM	5	ND	N	First Draw
Forsythe-33	Boys Locker Room, Bubblers	B	1:41 PM	5	1	N	First Draw
Forsythe-34	Pool, Bubblers	B	1:38 PM	5	200	N	First Draw. Observed Corrosion and Cloudy Water.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes	
Forsythe-35	Auditorium Lobby, Right Single Water Cooler	WC	1:46 PM	5	ND	N	First Draw	
Forsythe-36	Hallway, Across From Room 614, Bubbler	B	Not Sampled.					Scheduled to be replaced with a Hydration Station.
Forsythe-37	Hallway, Across From Room 501, Bubbler	B	Not Sampled.					Scheduled to be replaced with a Hydration Station.

Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Forsythe-01	Room 112, Wood Shop, Combination Sink Bubbler	B	11:35 AM	5	2	N	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminante>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Forsythe-03	Hallway, Outside Cafeteria, Hydration Station Bottle Fill	BF	10:47 AM	5	ND	N	First Draw
Forsythe-16	Hallway, Outside Cafeteria, Hydration Station Water Cooler	BF	10:48 AM	5	ND	N	First Draw
Forsythe-18	Hallway, Outside Room 401, Single Water Cooler	WC	10:40 AM	5	ND	N	First Draw
Forsythe-19	Hallway, Outside Room 412, Single Water Cooler	WC	10:35 AM	5	ND	N	First Draw
Forsythe-36	Hallway, Outside From Room 614, Single Water Cooler	WC	11:00 AM	5	ND	N	First Draw
Forsythe-37	Hallway, outside From Room 501, Hydration Station Water Cooler	WC	10:41 AM	5	ND	N	First Draw
Forsythe-38	Hallway, Outside From Room 501, Hydration Station Bottle Fill	WC	10:42 AM	5	ND	N	First Draw
Forsythe-39	Hallway, Outside Room 113, Hydration Station Bottle Fill	WC	10:55 AM	5	ND	N	First Draw
Forsythe-40	Hallway, Outside Room 113, Hydration Station Water Cooler	WC	10:56 AM	5	ND	N	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminante>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb