



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Haisley Elementary School

Date of Sampling: 10/20/2018

Sampler: Amanda Peterson

Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Haisley -43	Room 206, Faucet	C	10:56 AM	5	6	Y	First Draw
Haisley -45	Room 400, Faucet	C	11:24 AM	5	7	Y	First Draw
Haisley -49	Room 404, Faucet	C	11:30 AM	5	12	Y	First Draw
Haisley -64	Music Room, Faucet	F	10:36 AM	5	17	Y	First Draw

Haisley Elementary School

Date of Sampling: 12/08/2018

Sampler: Steven Ripley

Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Haisley -43A	Room 206, Faucet	C	3:25 PM	5	7	Y	Follow-up first draw following replacement.
Haisley -45A	Room 400, Faucet	C	3:20 PM	5	7	Y	Follow-up first draw following replacement.
Haisley -49A	Room 404, Faucet	C	3:30 PM	5	7	Y	Follow-up first draw following replacement.
Haisley -64	Music Room, Faucet	Location Removed					

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Haisley Elementary School							
Date of Sampling: 12/22/2018							
Sampler: Jenna Sendra							
Sample #	Location	Type ¹	Time Collected	Internal Action	Lead Results	Aerator Present	Notes
Haisley -43B	Room 206, Faucet	C	8:40 AM	5	5	Y	2nd Follow-up first draw following replacement.
Haisley -45B	Room 400, Faucet	C	8:44 AM	5	7	Y	2nd Follow-up first draw following replacement.
Haisley -49B	Room 404, Faucet	C	8:45 AM	5	8	Y	2nd Follow-up first draw following replacement.

Haisley Elementary School							
Date of Sampling: 1/19/2019							
Sampler: Jenna Sendra							
Sample #	Location	Type ¹	Time Collected	Internal Action	Lead Results	Aerator Present	Notes
Haisley -45C	Room 400, Faucet	C	8:52 AM	5	8	Y	3rd Follow-up first draw following replacement.
Haisley -49C	Room 404, Faucet	C	8:50 AM	5	53	Y	3rd Follow-up first draw following replacement.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861

Haisley Elementary School							
Date of Sampling: 2/02/2019							
Sampler: Alec Staber							
Sample #	Location	Type ¹	Time Collected	Internal Action	Lead Results	Aerator Present	Notes
Haisley -45D	Room 400, Faucet	C	12:16 PM	5	3	Y	4th Follow-up first draw following additional remediation activities.
Haisley -49D	Room 404, Faucet	C	12:19 PM	5	2	Y	4th Follow-up first draw following additional remediation activities.

1) Type: B = Bubble, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested

Action Level >5ppb