



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Huron High School							
Date of Sampling: March 29, 2019							
Sampler: Jessica Perfetti							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Huron-01	Hallway, Southeast Wing, Floor 1, Across from Room 6156, Bubbler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Huron-02	Hallway, Southeast Wing, Floor 1, Across from Main Office, Single Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Huron-03	Hallway, Southeast Wing, Floor 1, Across from Main Office, Hydration Station, Water Cooler	BF	8:59 AM	5	ND ³	N	First Draw, Corrosion noted on mouthpiece
Huron-04	Hallway, Southeast Wing, Floor 1, Across from Main Office, Hydration Station, Bottle Fill	BF	9:00 AM	5	ND	Y	First Draw, Build up noted on bottle fill
Huron-05	Fitness Center, Northwest Hydration Station, Bottle Fill	BF	10:26 AM	5	ND	Y	First Draw
Huron-06	Hallway, Southeast Wing, Floor 1, Outside of Media Center, Left Hydration Station, Water Cooler	BF	8:54 AM	5	ND	N	First Draw
Huron-07	Hallway, Southeast Wing, Floor 1, Outside of Media Center, Left Hydration Station, Bottle Fill	BF	8:55 AM	5	ND	Y	First Draw
Huron-08	Hallway, Northwest Wing, Outside of Cafeteria, Left Hydration Station, Water Cooler	BF	9:27 AM	5	ND	N	First Draw
Huron-09	Hallway, Northwest Wing, Outside of Cafeteria, Left Hydration Station, Bottle Fill	BF	9:28 AM	5	ND	Y	First Draw
Huron-10	Hallway, Northwest Wing, Floor 1, Outside Room 2100, Bubbler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Huron-11	Hallway, Northwest Wing, Floor 1, Across from Room 1100, Left Bubbler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Huron-12	Hallway, Northwest Wing, Floor 1, Outside Room 1110, Hydration Station Water Cooler	BF	10:22 AM	5	ND	N	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Huron High School							
Date of Sampling: March 29, 2019							
Sampler: Jessica Perfetti							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Huron-13	Open Number						
Huron-14	In Serving Area, East Faucet	F	9:42 AM	5	4	Y	First Draw
Huron-15	Fitness Center, Southeast Water Cooler	WC	10:29 AM	5	3	N	First Draw
Huron-16	Fitness Center, Northwest Hydration Station, Water Cooler	BF	10:27 AM	5	ND	N	First Draw
Huron-17	Center and Lower Gym, Hydration Station, Left Single Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Huron-18	Hallway, Northwest Wing, Floor 1, Between Fitness Center and Lower Gym, Right Single Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Huron-19	Pool, West Single Bubbler	B	10:38 AM	5	2	N	First Draw
Huron-20	Hallway, Northwest Wing, Outside of Cafeteria, Right Hydration Station, Water Cooler	BF	9:31 AM	5	ND	N	First Draw
Huron-21	Pool, East, Near Diving Boards, Single Bubbler	B	10:41 AM	5	ND	N	First Draw
Huron-22	Hallway, Northwest Wing, Outside of Cafeteria, Right Hydration Station, Bottle Fill	BF	10:17 AM	5	ND	Y	First Draw
Huron-23	Room 2103, Single 2-Compartment Sink	KF	10:17 AM	5	2	Y	First Draw
Huron-24	Room 2101, Single Sink Faucet	F	10:14 AM	5	ND	Y	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Huron High School							
Date of Sampling: March 29, 2019							
Sampler: Jessica Perfetti							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Huron-25	Cafeteria, East , Outside Service Area, Hydration Station, Water Cooler	BF	9:35 AM	5	ND	Y	First Draw
Huron-26	Cafeteria, West, Outside Kitchen, Hydration Station, Water Cooler	BF	10:08 AM	5	ND	N	First Draw
Huron-27	Kitchen, East Area, 2-Compartment Sink, Right Faucet	F	9:47 AM	5	ND	N	First Draw, Water observed to be lukewarm
Huron-28	Kitchen, East Area, 2-Compartment Sink, Left Faucet	F	9:48 AM	5	2	Y	First Draw, Water observed to be lukewarm
Huron-29	Kitchen, North Area, 3-Compartment Sink, Left Faucet	F	10:03 AM	5	ND	Y	First Draw, Water observed to be lukewarm
Huron-30	Kitchen, North Area, 3-Compartment Sink, Middle Faucet	F	10:04 AM	5	1	Y	First Draw, Water observed to be lukewarm
Huron-31	Kitchen, 3-Compartment Sink, Right Faucet	F	10:05 AM	5	1	Y	First Draw, Water observed to be lukewarm
Huron-32	Kitchen, North Area, Single Sink, Faucet	BF	9:50 AM	5	ND	Y	First Draw, Water observed to be lukewarm
Huron-33	Room 6152, Faucet	F	9:05 AM	5	ND	Y	First Draw
Huron-34	Hallway, Southeast Wing, Floor 1, Across from Room 7150, Hydration Station, Water Cooler	BF	9:12 AM	5	ND	N	First Draw
Huron-35	Hallway, Southeast Wing, Floor 1, Across from Room 7150, Right Bubbler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Huron-36	Hallway, Southeast Wing, Floor 1, Across from Room 7152, Left Bubbler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Huron High School							
Date of Sampling: March 29, 2019							
Sampler: Jessica Perfetti							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Huron-37	Hallway, Southeast Wing, Floor 1, Across from Room 7152, Right Bubbler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Huron-38	Hallway, Northwest Wing, Floor 2, Across from Room 3201, Hydration Station, Water Cooler	BF	11:16 AM	5	ND	N	First Draw
Huron-39	Hallway, Northwest Wing, Floor 2, Across from Room 3201, Left Bubbler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Huron-40	Room Between Room 2201 and Room 2200, 2-Compartment Sink Faucet "Green House"	KF	11:21 AM	5	ND	Y	First Draw
Huron-41	Hallway, Northwest Wing, Floor 2, Across from Room 2201, Left Bubbler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Huron-42	Hallway, Northwest Wing, Floor 2, Across from Room 2201, Hydration Station, Water Cooler	BF	11:24 AM	5	ND	N	First Draw
Huron-43	Dome Gym, South Single Bubbler	B	11:07 AM	5	3	N	First Draw
Huron-44	Dome Gym, North Single Bubbler	B	11:02 AM	5	1	N	First Draw
Huron-46	Hallway, Northwest Wing, Floor 2, Outside Upper Gym, Hydration Station, Water Cooler	BF	10:57 AM	5	ND	N	First Draw
Huron-47	Hallway, Northwest Wing, Floor 2, Outside Upper Gym, Hydration Station, Bottle Fill	BF	10:58 AM	5	ND	N	First Draw
Huron-48	Hallway, Northwest Wing, Floor 2, Outside Upper Gym, Single Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Huron-49	Upper Gym, Above Pool, Between Restrooms, Right Water Cooler	WC	10:52 AM	5	ND	N	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Huron High School							
Date of Sampling: March 29, 2019							
Sampler: Jessica Perfetti							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Huron-50	Upper Gym, Above Pool, Between Restrooms, Left Water Cooler	WC	10:53 AM	5	2	N	First Draw
Huron-51	Hallway, Southeast Wing, Floor 2, Across from Room 6212, Water Cooler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Huron-52	Room 6216, 2-Compartment Sink Faucet	F	11:56 AM	5	ND	Y	First Draw
Huron-53	Room 6218, 2-Compartment Sink Faucet	F	11:48 AM	5	1	Y	First Draw
Huron-54	Hallway, Southeast Wing, Floor 2, Outside Room 6203, Hydration Station, Water Cooler	BF	11:51 AM	5	ND	N	First Draw
Huron-55	Life Skills Room 6219, South Wall, 2-Compartment Kitchen Sink	F	11:41 AM	5	1	Y	First Draw
Huron-56	Life Skills Room 6219, East Wall, Right 2-Compartment Kitchen Sink	F	11:42 AM	5	1	N	First Draw
Huron-57	Life Skills Room 6219, East Wall, Middle 2-Compartment Kitchen Sink	F	11:43 AM	5	1	Y	First Draw
Huron-58	Life Skills Room 6219, East Wall, Left 2-Compartment Kitchen Sink	F	11:44 AM	5	2	Y	First Draw
Huron-59	Life Skills Room 6219, North Wall, Single 2-Compartment Kitchen Sink	F	11:39 AM	5	3	N	First Draw
Huron-60	Life Skills Room 6219, West Wall, 2-Compartment Kitchen Sink	F	11:33 AM	5	ND	Y	First Draw
Huron-61	Life Skills Room 6219, West Wall, Middle 2-Compartment Kitchen Sink	F	11:34 AM	5	ND	Y	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Pl...



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Huron High School							
Date of Sampling: March 29, 2019							
Sampler: Jessica Perfetti							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Huron-62	Life Skills Room 6219, West Wall, Right 2-Compartment Kitchen Sink	F	11:35 AM	5	ND	Y	First Draw
Huron-63	Life Skills Room 6219, Ice Machine	I	11:37 AM	5	ND	N	First Draw
Huron-64	Hallway, Southeast Wing, Floor 2, Across from Room 5200, Left Bubbler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Huron-65	Hallway, Southeast Wing, Floor 2, Across from Room 5200, Right Bubbler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Huron-66	Hallway, Floor 3, Outside Room 4311, Hydration Station, Bottle Fill	BF	12:10 PM	5	66	Y	First Draw
Huron-67	Hallway, Floor 3, Outside Room 4311, Hydration Station, Water Cooler	BF	12:11 PM	5	ND	N	First Draw
Huron-68	Hallway, Floor 3, Outside Room 4313, Hydration Station, Water Cooler	BF	12:06 PM	5	ND	N	First Draw
Huron-69	Hallway, Floor 3, Outside Room 4300, Bubbler	Not Sampled: Will be replaced with a Hydration Station or Filtered Water Cooler					
Huron-70	Hallway, Floor 3, Outside Room 4321, Hydration Station, Water Cooler	BF	12:02 PM	5	ND	N	First Draw
Huron-71	Hallway, Floor 1, Outside Room 7109, Hydration Station, Water Cooler	BF	9:19 AM	5	ND	N	First Draw
Huron-72	Hallway, Floor 1, Outside Room 7109, Hydration Station, Bottle Fill	BF	9:20 AM	5	ND	YY	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Huron High School							
Date of Sampling: March 29, 2019							
Sampler: Jessica Perfetti							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Huron-73	Hallway, Northwest Wing, Floor 1, Outside Room 1110, Hydration Station, Bottle Fill	BF	10:23 AM	5	ND	Y	First Draw
Huron-74	Cafeteria, East , Outside Service Area, Hydration Station, Bottle Fill	BF	9:36 AM	5	ND	Y	First Draw
Huron-75	Cafeteria, West, Outside Kitchen, Hydration Station, Bottle Fill	BF	10:09 AM	5	ND	Y	First Draw
Huron-76	Hallway, Southeast Wing, Floor 1, Across from Room 7150, Hydration Station, Bottle Fill	BF	9:13 AM	5	ND	Y	First Draw
Huron-77	Hallway, Northwest Wing, Floor 2, Across from Room 3201, Hydration Station, Bottle Fill	BF	11:17 AM	5	ND	Y	First Draw
Huron-78	Hallway, Northwest Wing, Floor 2, Across from Room 2201, Hydration Station, Bottle Fill	BF	11:25 AM	5	ND	Y	First Draw
Huron-79	Hallway, Southeast Wing, Floor 2, Outside Room 6203, Hydration Station, Bottle Fill	BF	11:52 AM	5	ND	Y	First Draw
Huron-80	Hallway, Floor 3, Outside Room 4313, Hydration Station, Bottle Fill	BF	12:07 PM	5	ND	Y	First Draw
Huron-81	Hallway, Floor 3, Outside Room 4321, Hydration Station, Bottle Fill	BF	12:03 PM	5	ND	Y	First Draw
Huron-82	Hallway, Floor 1, Outside Room 7109, Single Water Cooler	BF	9:21 AM	5	ND	N	First Draw
Huron-83	Hallway, Southeast Wing, Floor 1, Outside of Media Center, Right Hydration Station, Water Cooler	BF	8:56 AM	5	ND	N	First Draw
Huron-84	Hallway, Southeast Wing, Floor 1, Outside of Media Center, Right Hydration Station, Water Cooler	BF	8:57 AM	5	ND	Y	First Draw
Huron-85	Kitchen, Northwest Corner, ice Machine	I	9:53 AM	5	ND	N	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested