



Ann Arbor Public Schools  
 Lead Drinking Water Analysis  
 Project Number: AE180861

Logan Elementary School							
Date of Sampling: 11/17/2018							
Sampler: Lauren Koloski							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Logan ES-01	Hallway, Outside Room 262, Water Cooler	WC	7:23 AM	5	1	N	First Draw. Water cooler was reviewed against the EPA Fact Sheet to determine that it is not a lead lined.
Logan ES-02	Teacher's Lounge, Faucet	KF	7:24 AM	5	6	Y	First Draw
Logan ES-03	Gym Kitchen 2-Compartment Sink	KF	7:25 AM	5	3	Y	First Draw
Logan ES-04	Hallway, Outside of Room C-256, Bottle Fill Outlet	BT	7:32 AM	5	ND <sup>3</sup>	N	First Draw
Logan ES-05	Media Center, Right of East Teacher's Work Room, Left Water Cooler	WC	7:36 AM	5	ND	N	First Draw. Water cooler was reviewed against the EPA Fact Sheet to determine that it is not a lead lined.
Logan ES-06	Media Center, Right of East Teacher's Work Room, Right Water Cooler	WC	7:36 AM	5	ND	N	First Draw. Water cooler was reviewed against the EPA Fact Sheet to determine that it is not a lead lined.
Logan ES-07	Room 324, Bubbler	C	8:17 AM	5	1	N	First Draw
Logan ES-08	Media Center, Right of West Teacher's Work Room, Bottle Fill, Water Cooler Outlet	BT	8:37 AM	5	ND	N	First Draw
Logan ES-09	Media Center, Right of West Teacher's Work Room, Single Water Cooler	WC	8:37 AM	5	ND	N	First Draw. Water cooler was reviewed against the EPA Fact Sheet to determine that it is not a lead lined.
Logan ES-10	Room 240, Bubbler	C	7:52 AM	5	7	N	First Draw
Logan ES-11	Room 234, Faucet	C	8:01 AM	5	6	Y	First Draw
Logan ES-12	Room 220, Bubbler	C	8:12 AM	5	3	N	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



Ann Arbor Public Schools  
 Lead Drinking Water Analysis  
 Project Number: AE180861

Logan Elementary School							
Date of Sampling: 11/17/2018							
Sampler: Lauren Koloski							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Logan ES-13	Room 324, Faucet	C	8:17 AM	5	6	N	First Draw. Corrosion Around Handles.
Logan ES-14	Room 326, Bubbler	C	8:20 AM	5	2	N	First Draw
Logan ES-15	Room 326, Faucet	C	8:20 AM	5	9	Y	First Draw. Corrosion Around Handles.
Logan ES-16	Room 328, Bubbler	C	8:22 AM	5	1	N	First Draw
Logan ES-17	Room 328, Faucet	C	8:22 AM	5	38	Y	First Draw
Logan ES-18	Room 330, Bubbler	C	8:25 AM	5	3	N	First Draw. Bubbler Was Bagged Prior to Sampling.
Logan ES-19	Room 330, Faucet	C	8:25 AM	5	7	Y	First Draw
Logan ES-20	Room 332, Bubbler	C	8:27 AM	5	ND	N	First Draw
Logan ES-21	Room 332, Faucet	C	8:27 AM	5	9	Y	First Draw
Logan ES-22	Room 333, Bubbler	C	8:25 AM	5	ND	N	First Draw
Logan ES-23	Room 333, Faucet	C	8:25 AM	5	3	Y	First Draw
Logan ES-24	Room 335, Bubbler	C	8:35 AM	5	ND	N	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminante>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



Ann Arbor Public Schools  
 Lead Drinking Water Analysis  
 Project Number: AE180861

Logan Elementary School							
Date of Sampling: 11/17/2018							
Sampler: Lauren Koloski							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Logan ES-25	Room 335, Faucet	C	8:35 AM	5	ND	N	First Draw
Logan ES-26	Room 212, Bubbler	C	8:15 AM	5	4	N	First Draw
Logan ES-27	Room 212, Faucet	C	8:15 AM	5	8	Y	First Draw
Logan ES-28	Room 220, Faucet	C	8:12 AM	5	4	Y	First Draw. Low Flow.
Logan ES-29	Room 224, Bubbler	C	8:10 AM	5	3	N	First Draw. Corrosion Around Mouthpiece.
Logan ES-30	Room 224, Faucet	C	8:10 AM	5	8	Y	First Draw. Scale and Corrosion Around Handle and Aerator.
Logan ES-31	Room 230, Bubbler	C	8:02 AM	5	3	N	First Draw
Logan ES-32	Room 230, Faucet	C	8:02 AM	5	4	Y	First Draw
Logan ES-33	Room 233, Bubbler	C	8:05 AM	5	3	N	First Draw
Logan ES-34	Room 233, Faucet	C	8:05 AM	5	5	Y	First Draw
Logan ES-35	Room 234, Bubbler	C	8:01 AM	5	2	N	First Draw
Logan ES-36	Room 236, Bubbler	C	8:00 AM	5	6	N	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



Ann Arbor Public Schools  
 Lead Drinking Water Analysis  
 Project Number: AE180861

Logan Elementary School							
Date of Sampling: 11/17/2018							
Sampler: Lauren Koloski							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Logan ES-37	Room 236, Faucet	C	8:00 AM	5	7	Y	First Draw. Corrosion on Aerator.
Logan ES-38	Room 238, Bubbler	C	7:55 AM	5	2	N	First Draw
Logan ES-39	Room 238, Faucet	C	7:55 AM	5	42	Y	First Draw
Logan ES-40	Room 240, Faucet	C	7:52 AM	5	11	Y	First Draw. Build-up on Aerator.
Logan ES-41	Room 241, Bubbler	C	7:50 AM	5	4	N	First Draw
Logan ES-42	Room 241, Faucet	C	7:50 AM	5	12	Y	First Draw
Logan ES-43	Room 243, Bubbler	C	7:45 AM	5	7	N	First Draw
Logan ES-44	Room 243, Faucet	C	7:45 AM	5	9	Y	First Draw
Logan ES-45	Room 250, Bubbler	C	7:42 AM	5	7	N	First Draw
Logan ES-46	Room 250, Faucet	C	7:42 AM	5	22	Y	First Draw. Corrosion on Aerator.
Logan ES-47	Room 253, Bubbler	C	7:38 AM	5	9	N	First Draw. Low Flow.
Logan ES-48	Room 253, Faucet	C	7:38 AM	5	13	Y	First Draw. Corrosion on Aerator.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



Ann Arbor Public Schools  
 Lead Drinking Water Analysis  
 Project Number: AE180861

Logan Elementary School							
Date of Sampling: 11/17/2018							
Sampler: Lauren Koloski							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Logan ES-49	Kitchen, 3-Compartment Sink, Left Faucet	KF	7:30 AM	5	3	Y	First Draw
Logan ES-50	Kitchen, 3-Compartment Sink, Right Faucet	KF	7:30 AM	5	ND	Y	First Draw
Logan ES-51	Media Center, Right of West Teacher's Work Room, Bottle Fill Outlet	BT	8:37 AM	5	1	N	First Draw
Logan ES-52	Hallway, Outside Room C-256 Bottle Fill, Water Cooler Outlet	BT	7:32 AM	5	1	N	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



Ann Arbor Public Schools  
 Lead Drinking Water Analysis  
 Project Number: AE180861

Logan Elementary School							
Date of Sampling: 2/02/2019							
Sampler: Alec Staber							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Logan ES-01	Hallway, Outside Room 262, Hydration Station Water Cooler	BT	8:48 AM	5	ND	N	First Draw. New Hydration Station.
Logan ES-53	Hallway, Outside Room 262, Hydration Station Bottle Fill	BT	8:49 AM	5	ND	N	First Draw. New Hydration Station.
Logan ES-54	Multi-Use/Cafeteria, Small Entry Hallway, Outside Kitchen Door, Single Water Cooler	WC	8:53 AM	5	ND	N	First Draw. New Hydration Station.
Logan ES-55	Multi-Use/Cafeteria, Small Entry Hallway, Outside Kitchen Door, Hydration Station Bottle Fill	BT	8:54 AM	5	ND	N	First Draw. New Hydration Station.
Logan ES-56	Multi-Use/Cafeteria, Small Entry Hallway, Outside Kitchen Door, Hydration Station Water Cooler	BT	8:55 AM	5	ND	N	First Draw. New Hydration Station.
Logan ES-05	Media Center, Right of East Teacher's Work Room, Outside Room C-233, Hydration Station Water Cooler	BT	8:58 AM	5	ND	N	First Draw. New Hydration Station.
Logan ES-57	Media Center, Right of East Teacher's Work Room, Outside Room C-233, Hydration Station Bottle Fill	BT	8:59 AM	5	ND	N	First Draw. New Hydration Station.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested